

Batraz Pagaev

T 6613 KA

COMPARATIVE ANALYSIS of
HEATING SYSTEMS of SHOPPING
CENTER

Bachelor's Thesis
Building Services Engineering


January 2014



MIKKELIN AMMATTIKORKEAKOULU

Mikkeli University of Applied Sciences

DESCRIPTION

| | | |
|---|--|---|
|  <p>MIKKELIN AMMATTIKORKEAKOULU Mikkeli University of Applied Sciences</p> | | Date of the bachelor's thesis 14 January 2014 |
| Author(s) Batraz Pagaev | Degree programme and option Double Degree Programme in Building Services Engineering | |
| Name of the bachelor's thesis Comparative Analysis of Heating Systems of Shopping Center | | |
| Abstract <p>In this thesis is examined a shopping center located in St. Petersburg. The main purpose of this thesis is to compare heating systems and decide which one is more suitable for a shopping center.</p> <p>The work consists of theoretical and practical parts. The theoretical part shows the features of the shopping center, two heating systems, their classifications and design features. The practical part consists of thermal and financial calculations which are necessary for comparing the systems. All the calculations were made according to the Russian building norms and regulations.</p> <p>As a result of the comparison the individual heating system with a roof gas boiler plant was defined as a more effective and economical solution for heating a shopping center.</p> | | |
| Subject headings, (keywords) Heating system, district heating, boiler plant, heat load, operating costs | | |
| Pages 27 p. | Language English | URN |
| Remarks, notes on appendices | | |
| Tutor Jarmo Tuunanen | Employer of the bachelor's thesis | |

CONTENT

LIST OF SYMBOLS

| | | |
|-------|---|----|
| 1 | INTRODUCTION..... | 1 |
| 2 | GENERAL | 2 |
| 2.1 | Aims..... | 2 |
| 2.2 | Methods | 2 |
| 2.3 | Background..... | 3 |
| 2.4 | District heating system | 4 |
| 2.4.1 | District heating system structure..... | 4 |
| 2.4.2 | Direct and indirect scheme of district heating connection..... | 5 |
| 2.4.3 | Open and closed scheme of DH connection | 7 |
| 2.5 | Individual heating system with roof gas boiler plant..... | 7 |
| 3 | DESIGNING THE HEATING SYSTEMS | 10 |
| 3.1 | Description of the building | 10 |
| 3.2 | Selection of heating systems for shopping center..... | 13 |
| 3.3 | Designing DH system | 13 |
| 3.4 | Designing heating system with roof gas boiler plant..... | 15 |
| 4 | THERMAL CALCULATION OF BUILDING COMPONENTS | 17 |
| 4.1 | Calculation of normalized values of thermal resistance of a building component..... | 17 |
| 4.2 | Calculation of actual values of thermal resistance of a building component..... | 18 |
| 4.3 | Heat loss calculation | 19 |
| 5 | FINANCIAL CALCULATION..... | 20 |
| 5.1 | Initial date | 20 |
| 5.2 | Calculation of the approximate annual cost of heat..... | 20 |
| 5.3 | Calculation of roof boiler plant cost | 21 |
| 6 | COMPARISON OF THE SYSTEMS | 22 |
| 7 | CONCLUSION..... | 24 |
| | BIBLIOGRAPHY..... | 26 |
| | Appendix 1 | |
| | Appendix 2 | |

LIST OF SYMBOLS

| | |
|--------------------------|--|
| α_{ext} | heat transfer coefficient of the outer surface of the enclosing structure with the conditions of the cold period, $\text{W} / \text{m}^2 \cdot ^\circ\text{C}$ |
| α_{int} | heat transfer coefficient of the inner surfaces of the enclosing structure, $\text{W} / \text{m}^2 \cdot ^\circ\text{C}$ |
| A | area of the enclosing structure, m^2 |
| d | thickness of material layer, m |
| D_d | degree-day value, $^\circ\text{C} \cdot \text{day}$ |
| k | coefficient of heat transfer, $\text{W} / \text{m}^2 \cdot ^\circ\text{C}$ |
| M_{DH} | annual cost of heat for district heating system, euro/year |
| M_{RB} | annual cost of heat for individual heating system, euro/year |
| N | annual operating time of the heating system, hour |
| Q | heat loss through the building envelope, kW |
| Q_h | total heat load of shopping center, kWh |
| Q_{TOT} | total heat load of building during the heating period, kW/year |
| R | thermal resistance of the building component, $\text{m}^2 \cdot ^\circ\text{C}/\text{W}$ |
| R_1, R_2, \dots, R_n | thermal resistances of the individual layers enclosing structure, $\text{m}^2 \cdot ^\circ\text{C}/\text{W}$ |
| $R_{a,1}$ | thermal resistance of an air cavity in the building component, $\text{m}^2 \cdot ^\circ\text{C}/\text{W}$ |
| R_o | thermal resistance of the building component with serial homogeneous layers, $\text{m}^2 \cdot ^\circ\text{C}/\text{W}$ |
| R_{reg} | normed thermal resistance of a building component, $\text{m}^2 \cdot ^\circ\text{C}/\text{W}$ |
| R_T | thermal resistance of the enclosing structure, $\text{m}^2 \cdot ^\circ\text{C}/\text{W}$ |
| T_B | design indoor air temperature, $^\circ\text{C}$ |
| T_H | design outdoor air temperature, $^\circ\text{C}$ |
| T_{ht} | the average value of outdoor air temperature, $^\circ\text{C}$ |
| T_{int} | the average value of indoor air temperature of the building, $^\circ\text{C}$ |
| t_{out} | design winter outdoor temperature, $^\circ\text{C}$ |
| $t_{\text{out,average}}$ | average temperature during the heating period, $^\circ\text{C}$ |
| $V_{\text{gas,year}}$ | annual volume of gas, required for heating, m^3 |
| Z_{ht} | duration of heating period, days |
| β | additional heat losses |
| λ | design thermal conductivity of material layer, $\text{W} / \text{m}^2 \cdot ^\circ\text{C}$ |

1 INTRODUCTION

Living in countries where the main part of the year is cold, it is necessary to provide heating for buildings: residential buildings, offices and other premises. Heat provides comfortable accommodation, if it is an apartment or a house, and productive work, if it is an office or warehouse. Heat supply of buildings has become one of the most pressing issues in the recent years. First of all, this situation is interesting for the owners of social facilities, office buildings and industrial plants. One of the objects of the social sphere in need of heat supply is shopping centers.

In Russia there are more and more shopping centers - high-rise buildings with big amounts of premises for shops and offices. The correct calculations and the correct design of all the systems are important parts in a successful opening of a shopping center. The design and the calculation of the heating system plays an important role for the construction of a shopping center. However, for the correct design it is necessary to understand the characteristics of a heating system. The heating system is the heat supply of residential, public and industrial buildings to provide the municipal and the technological needs of consumers.

Naturally, the question arises what kind of the heating system should be applied for shopping center buildings. Indeed, there are a number of technical solutions to this problem. The choice must be based on the specific conditions in order to offer the best solution both in technique and the cost of equipment and labor. In this case, typically the customer always wants to get the best option at an affordable cost.

However one shouldn't forget that the system must be reliable. Such thing as a reliability of heat supply is particularly important. Shopping centers are facilities that serve people. It means that the failure in the operation of heating systems will cause changes in the indoor climate and the appearance of discomfort for humans. Therefore it is necessary to make correct calculations and properly design the entire system in order to subsequently save energy, time and money.

2 GENERAL

2.1 Aims

A thesis has several aims. The first aim is the familiarization with the heating systems of shopping centers. The second goal is to select two types of heating systems. The next aim is to compare the selected systems and to make a comparative table of the results. The resulting table will show the advantages and disadvantages of each system. The final or the main aim is to select the most efficient and economical heating system for a shopping center.

2.2 Methods

The following methods will be used to achieve the aims. The first method is to review the literature. The main sources are magazine articles, and information provided by companies operating in field of heat supply. The information describing the operating principles of heating systems will also be used. This method will show the characteristics of heating systems in more detail and will help to choose the most beneficial options for heating systems.

Two types of heating systems will be chosen. One of the shopping centers under construction in St. Petersburg will be selected for consideration of these systems. The second method is the design and the calculation of the heating systems. In this part the heat demand of the building and the approximate annual cost of heat will be calculated. The method of designing will help to become more familiar with the structure of systems. The next method is the financial calculation. This method will show the economic efficiency of the heating systems and will serve as one of the main criteria for selecting the more effective system.

The last method but also an important is comparison of these types of heating system and analyzing results. Advantages and disadvantages of one system relative to another will be shown. Result of the comparison will play a major role in selecting the most efficient and economical heating system. The result also shows in which situations we can use a particular system.

2.3 Background

Heating commercial premises is necessary for maintaining a certain temperature inside the building and doesn't depend on the time of year. The premises shouldn't be too hot or too cold. The premises must to have a good indoor climate. It's rather difficult to select the heat source. We must consider several important factors: the size of the areas, the required heat capacity, heat demands, the natural conditions (extreme cold or southern winters) and so on.

The heating systems can be divided into district or distributed systems. Distributed heating system or individual heating system serves one or more buildings, while the district heating system or the centralized system serves residential or industrial areas. These classifications of heating systems are based on the heat source used. CHP plant and boiler plant are the main sources of heat for rooms with a large area.

There are many different types of fuels. The main fuels are wood, gas, oil, coal. Each fuel used has benefits; cost, efficiency. The four main mediums for conveying heat are: air, water, steam and electricity. Heating systems can be classified into four types: hydronic heating systems, warm-air heating system, electric heating systems and steam heating systems

Hydronic systems

Hydronic systems use water as the medium for delivering the heat to the various rooms and spaces within a structure. In a typical hot-water heating system, water is heated in a boiler or water heater, and circulated through pipes to baseboard convectors or radiators located in various rooms. /1, p.149./

Warm-air systems

Warm-air system is advantageous to be used in commercial and industrial buildings with a large area and high ceilings. The advantage of this type of heating is the fact that you can adjust the temperature of the air flow, and in the warmer months, use it as a conditioner. In the recent years the presence of air heat curtains can be often observed at the entrance to the stores and shopping centers. Air curtains are installed at

the entrance to a store, and make a powerful warm shield, thus preventing the penetration of cold air inside. /2./

Electric system

The most simple, safe and convenient system for the installation is a system of electric heating. Such a system is totally dependent on an external source of electricity. Therefore, electric heating is most commonly used for offices and buildings that don't need to maintain the room temperature all year round and 24 hours a day.

2.4 District heating system

District heating is a heating system of large residential areas, cities, towns and industrial plants. District heating (DH) is a widely used form of heating for commercial building in such as shopping centers.

2.4.1 District heating system structure

The DH system consists of the following main parts: heat source, heat networks, substations and customer connection. Figure 1 shows the main component of district heating system in Russia. The source of heat in district heating is a combined heat and power plant (CHP) or a boiler plant. The thermal capacity of modern CHP reaches 2300-4600 MW, the district boiler 110-580 MW /3, p.6/.

Hot water and vapour serve as the main heat transfer media in the systems of district heat supply. The temperature of DH water depends on the design parameters of the whole DH system and the parameters of the boiler plant. District heating networks are mainly made two-piped. The system network consists of two kinds of pipelines: a pipeline for supplying hot water from the heat source to the system of heat consumption and a return pipeline. According to the Russian standards, the temperature in DHW network should not be less than $+60^{\circ}\text{C}$ /4. p.13/. The selection of the temperature and pressure in heating systems is determined by the requirements of consumers and economic considerations.




FIGURE 1. Main components of District Heating System in Russia

2.4.2 Direct and indirect scheme of district heating connection

There are two schemes of district heating network connection to buildings: direct and indirect. In the direct systems, hot water from the heat network goes directly to heat emitters of consumers. This type of connection is illustrated in Figure 2.

Direct system

Direct DH system has several advantages. There are neither heat exchangers, heat points nor hydraulic isolation. It's simple to operate a direct system and it doesn't require any additional equipment, such as circulation pumps, automatic regulation and control devices, heat exchangers, etc.




FIGURE 2. Direct DH system

Indirect system

In the indirect systems hot water goes initially to the heat exchanger, where this water heats and after that it goes to radiators. A heat exchanger is installed in the substations. In Figure 3 there is the scheme of indirect connection of DH system. Such systems as indirect DH systems are used mainly in large cities - in order to improve the reliability of heat.




FIGURE 3. Indirect DH system

The indirect heating system has a number of advantages: the opportunity to control the amount of heat delivered to the consumer by adjusting the secondary fluid; its higher reliability and energy-saving effect, in such systems the heat savings is 10-40%. It is also possible to improve the operational and technical qualities of a heat transfer medium, which significantly improves the protection of boiler systems from contamination.

2.4.3 Open and closed schemes of DH connection

A domestic hot water connection is divided into open and closed. Figure 4 shows the difference between the open and close connection of DHW.




FIGURE 4. Open or closed DH system /5, p.25/

2.5 Individual heating system with a roof gas boiler plant

Currently individual heating systems, like a roof boilers, are becoming more popular. An autonomous (individual) boiler plant is a boiler room designed to heat a building or structure. So, the roof boiler of public buildings should provide reliable energy efficient and safe supply of the consumers with hot water and heat during operation, without a permanent staff.

Boiler plants as intended are divided into: boiler plants which provide heat to the heating, ventilation and hot water systems; boiler plants which provide heat to heating,

ventilation, hot water and technological systems and boiler plants for technological heat supply.

Figure 5 shows the main part of a roof gas boiler plant. Automated heat generators or boilers should be used as a source of heat in the roof boiler plant. The main fuel for the roof boiler plant is natural gas. It is also possible to use diesel, waste oil and ma-sut. The heating capacity of such boiler should not exceed the heat demand of the building. In boiler plants there must be at least two boilers. The installation of one boiler is allowed in the industrial boiler plants of the second category. The automatic control unit is installed in the modern roof boiler plant. This control unit regulates the system in accordance with the temperature values. The main heat transfer media is water at a temperature up to 95 ° C, and pressure up to 1.0 MPa /6, p.2/.

The environmental safety is an important property, which a roof boiler plant has. It is an important advantage over other types of boilers. The fact is that being on the roof, gases have greater access to the open atmosphere, so that their removal is much easier compared to a conventional gas outlet. In the conventional gas outlet, the combustion gases are displaced upward along the pipe.




FIGURE 5. Gas boiler plant /7/

There are two main circuits of a connection between heat generators: parallel and serial. The parallel circuit is the inclusion of heat generators in parallel. Thus, each of them may be operating, and the backup heat source. In order to maintain a constant flow of water through the heat generator, each of them is equipped with a circulation pump. An entire chain of heat generators is equipped with a total recirculation line, check valve and pressure regulators. A series circuit is the inclusion of heat generators with their pump in series with each other. Each heat generator is equipped with recirculation line. /8, p.6./

The scheme of the roof boiler plant with a parallel circuit of connection between heat generators is illustrated in Figure 6. The scheme of the roof boiler plant with a serial circuit of connection is illustrated in Figure 7.




FIGURE 6. The scheme of a roof boiler plant with a parallel circuit of connection between heat generators /8, p.6/

The scheme with a parallel circuit consists of the following elements: 1 – heat generator; 2, 3, 5 - circulation pump; 4 - waterheater; 6 - two-way control valve; 7 – three-way control valve; 8 - check valve; 9 - gas control valve; 10 - gas meter; 11 – CW meter; 12 - HDW temperature regulator ; 13 – water temperature regulator for heating; 14 – the sensor of flow limiting device; 15, 17 - water temperature sensors; 16 –

control box; 18 – outdoor air temperature sensor; 19 – safety valve; 20 - regulator of water temperature after heat generator; 21 - mud trap; 22 - recirculation line; 23 - pressure drop regulator.




FIGURE 7. The scheme of a roof boiler plant with a serial circuit of connection between heat generators /8, p.6/

The scheme with a serial circuit consists of the following elements: 1 - heat generator; 2, 11 - circulation pump; 3 - gas flow regulator; 4 - regulator of water temperature after heat generator;; 5 - the sensor of flow limiting device; 6 - HDW temperature regulator; 7 - water temperature sensor; 8 - check valve; 9 - waterheater; 10 – mud trap; 12 - CW meter; 13 - three-way control valve; 14 - safety valve; 15 - gas meter

3 DESIGNING THE HEATING SYSTEMS

3.1 Description of the building

The multifunctional complex " U Krasnogo Mosta" has been chosen as the object of designing. The multifunctional complex is located on the Moika Embankment, in St. Petersburg. Figure 8 shows the facade of the shopping center. This complex is an object under restoration and reconstruction of the historic buildings in shopping destina-

tion in the city center. The multifunctional complex will be a seven-story building with the most modern solutions in the field of security and the latest automatic control of all the utilities. The roomy automated underground parking will be built in the complex. The building area is 12126.3 m². The building has similar floor plans. Figure 9 shows the floor plan.



FIGURE 8. Multifunctional complex " U Krasnogo Mosta" /9/

The current shopping center is located in the northern part of Russia. There are several estimated parameters of the outside air during the cold season:

- The design winter outdoor temperature $t_{out} = -26\text{ }^{\circ}\text{C}$
- The average temperature during the heating period $t_{out,average} = -1.8\text{ }^{\circ}\text{C}$
- The duration of the heating period: $Z_{ht} = 220\text{ days /13/}$.




FIGURE 9. Example of a floor plan

3.2 Selection of heating systems for a shopping center

Today, there are many systems that can heat a room with a large area. For each object it is necessary to select the most beneficial heating system. For choosing a heating system it is necessary to study the external and internal factors: the location of the object, climatic conditions, the number of storeys of the building and internal climate.

After examining the features of the location of the object, its structure was determined that for a given object can be used both district and distributed heating system. Two heating systems with different heat sources were chosen for the comparison:

- district heating system
- individual heating system with a roof gas boiler plant

Both of these systems are best suited for this shopping center. Each system has both its own requirements and characteristics, together with the advantages and disadvantages.

3.3 Designing DH system

A heat source for the district heating system of the current shopping center will be the a Central CHP plant. The Central CHP plant has certain technological facts: generated electric power - 75.5 MW, generated thermal capacity - 1600 MW /10/. Gas is used as a main fuel, masut- as a reserve fuel.

A hot water with parameters 90/70 °C will be the main heat transfer media in the system. The network of the system will be with indirect connection and two pipes with bottom distributing. Radiators and convectors of "PURMO" will be used as heat emitters. The building has similar floor plans. The scheme of a connection of the heat emitters is illustrated in Figure 10 and Figure 11.




FIGURE 10. Scheme of a connection of the heat emitters to the heat riser




FIGURE 11. Scheme of a connection of the heat emitters

3.4 Designing a heating system with a roof gas boiler plant

Two boilers will be used as a main heat source: boiler « Viessmann Vitoplex-200-270" and boiler « Viessmann Vitoplex-200-200» with burners «Weishaupt» WM-G 20/2. Figure 12 illustrates the selected gas boiler and Figure 13 shows the roof gas boiler plant for the current shopping center. Table 1 shows the technical information of boilers.

TABLE 1. Technical information of boilers /11/

| Technical information | Type of boiler | |
|--------------------------------------|------------------|------------------|
| | Vitoplex-200-200 | Vitoplex-200-270 |
| Nominal thermal capacity, kW | 200 | 270 |
| Max Permissible flow temperature | 110 °C (120 °C) | |
| Operating temperature, °C | 95 | |
| Operating pressure, bar | 4 | |
| The volume of water in the boiler, l | 300 | 400 |
| Gas consumption per 1 kW , m3 | 0,105 | |
| Standard efficiency η , % | 89 | |

A hot water with a parameters 90/70 °C will be used as the main heat transfer media in the system. The network of the system will be with the indirect connection and two pipes with bottom distributing. Radiators and convectors of "PURMO" will be used as

heat emitters. The source of a gas for boiler plant is a medium pressure gas pipeline $P = 98.1 \text{ kPa}$.



FIGURE 12. Gas boiler /11/




FIGURE 13. A roof gas boiler plant for the current shopping center

4 THERMAL CALCULATIONS OF BUILDING COMPONENTS

4.1 The calculation of normalized values of the thermal resistance of a building component

The calculations are based on the Russian building norms and regulations SNiP 23-02-2003 "Thermal protection of buildings". The thermal resistance of the building components R_o , $m^2 \cdot ^\circ C/W$, should not be less than normed thermal resistance R_{reg} , $m^2 \cdot ^\circ C/W$. The normed thermal resistance R_{reg} is defined in Table 4 of SNiP and depends on the degree-day value D_d , $^\circ C \cdot day$. /12, p.7./ The degree-day value D_d :

$$D_d = (T_{int} - T_{ht}) Z_{ht}, \quad (1)$$

where:

T_{int} - the average value of indoor air temperature of the building, $^\circ C$:

T_{ht} - the average value of outdoor air temperature, $^\circ C$, to be considered for the period with an average daily temperature of the outside air is not more than $8^\circ C$:

Z_{ht} – duration of heating period, days.

The current shopping center has its own temperatures:

$$T_{int} = + 20^\circ C.$$

$$T_{int} = + 5^\circ C \text{ (for car parking)}$$

$$T_{ht} = -1,8^\circ C;$$

$$Z_{ht} = 220 \text{ days}$$

The degree-day value D_d :

$$D_d = (20 + 1.8) \cdot 220 = 4796^\circ C \cdot day \quad (2)$$

$$D_d = (5 + 1.8) \cdot 220 = 1496^\circ C \cdot day /13/$$

Normalized values of thermal resistance of a building component are shown in Table 2.

TABLE 2. Normalized values of the thermal resistance of a building component /12/

| Buildings and premises | The degree-day value D_d , °C·day | Normed thermal resistance R_{reg} , $m^2 \cdot ^\circ C / W$, of a building component | | | |
|---|-------------------------------------|--|---------------------|----------------------------|-----------------|
| | | wall | floors and ceilings | Loft and basement ceilings | Window and door |
| Public, administrative and domestic buildings | 4796 | 2,64 | 3,52 | 2,98 | 0,44 |
| Car parking | 1496 | 1,3 | 1,874 | 1,3 | 0,24 |

4.2 Calculation of actual values of thermal resistance of a building component

Calculations are based on the Russian building norms and regulations SNiP 23-101-2004 "Design of thermal protection of buildings". The thermal resistance R $m^2 \cdot ^\circ C / W$ of the building component is defined by the formula 3.

$$R = d / \lambda \quad (3)$$

where:

d - thickness of material layer 1, 2, ... m, m;

λ - design thermal conductivity of material layer 1, 2, ... m, e.g. normative thermal conductivity, $W / m^2 \cdot ^\circ C$.

The thermal resistance R_o $m^2 \cdot ^\circ C / W$ of the building component with serial homogeneous layers is determined by the formula 4:

$$R_o = \frac{1}{\alpha_{int}} + R_T + \frac{1}{\alpha_{ext}} \quad , \quad (4)$$

where:

α_{int} - heat transfer coefficient of the inner surfaces of the enclosing structure, $W / m^2 \cdot ^\circ C$;

α_{ext} - heat transfer coefficient of the outer surface of the enclosing structure with the conditions of the cold period, $\text{W} / \text{m}^2 \cdot ^\circ\text{C}$;

R_T - the thermal resistance of the enclosing structure, $\text{m}^2 \cdot ^\circ\text{C}/\text{W}$.

The total thermal resistance R_T of the building components is calculated using the formula 5:

$$R_T = R_1 + R_2 + \dots + R_n + R_{a.l.}, \quad (5)$$

where:

R_1, R_2, \dots, R_n - thermal resistances of the individual layers enclosing structure, $\text{m}^2 \cdot ^\circ\text{C}/\text{W}$;

$R_{a.l.}$ - thermal resistance of an air cavity in the building component, $\text{m}^2 \cdot ^\circ\text{C}/\text{W}$

A coefficient of heat transfer k of the enclosing structure is determined by the formula:

$$k = \frac{1}{R_0} \quad (6)$$

The results of the calculations of the thermal resistance of building component and heat transfer coefficients are given in Appendix 1.

4.3 Heat loss calculation

Heat loss through the building envelope is calculated in accordance with Russian building norms and regulations SNIIP 2.04.05-91 "Heating, Ventilation and Air Conditioning" by the formula:

$$Q = A \cdot (T_B - T_H) \cdot n \cdot (1 + \sum \beta) \cdot k \quad (7)$$

where:

A - area of the enclosing structure, m^2 ;

T_B – design indoor air temperature, $^\circ\text{C}$;

T_H - design outdoor air temperature, $^\circ\text{C}$;

β - additional heat losses;

k - coefficient of heat transfer, $\text{W} / \text{m}^2 \cdot ^\circ\text{C} \cdot /15./$

The results of the calculation of heat loss are given in Appendix 2.

5 FINANCIAL CALCULATIONS

5.1 Initial date

Heating costs are determined depending on different factors: the area of the building, the type of heating medium and components of heating system. The most obvious factor affecting the price is the area of the building.

Appendix 2 shows that the total heat load of shopping center $Q_h = 366.2 \text{ kW}$

Duration of the heating period: $Z_{ht} = 220 \text{ days}$

The annual operating time of the heating system is calculated by the formula:

$$N = 24 \cdot Z_{ht} = 24 \cdot 220 = 5280 \text{ hours} \quad (8)$$

The total heat load of building during the heating period is calculated by formula:

$$Q_{TOT} = N \cdot Q_h \quad (9)$$

$$Q_{TOT} = 5280 \cdot 366.2 \text{ kW} = 1933536 \text{ kW/year} = 1933.54 \text{ MW/year}$$

5.2 Calculation of the approximate annual cost of heating

District heating system

The price of district heating in Russia depends on the city in which the building is located. The price of the district heating for Saint-Petersburg consumers is 0.027 euro/kWh. The heat tariffs are for 2013 /16/.

The annual cost of heating:

$$M_{DH} = Q_{TOT} \cdot 0.027 = 1933536 \text{ kW} \cdot 0.027 \text{ euro/kW} = 52205.47 \text{ euro/ year.}$$

Individual heating system with a roof gas boiler plant

Natural gas is used as a fuel for a roof boiler plant of the shopping center. The price of natural gas in Russia depends on the city in which the building is located. The price of the natural gas for the Saint-Petersburg consumers is 0.112 euro/ m³ /16/. The natural gas tariffs are 2013.

In accordance with the specifications of boilers, the required volume of natural gas for producing of 1 kW of heat is equal to 0,105 m³ /11/. Thus, burning 1 m³ of natural gas

produces 8,1 kW of heat taking into account efficiency. The annual volume of gas, required for heating, is calculated by formula:

$$V_{\text{gas,year}} = Q_{\text{TOT}}/q_N \quad (10)$$

$$V_{\text{gas,year}} = 1933536 \text{ kW} / 8,1 \text{ kW/m}^3 = 238708,14 \text{ m}^3$$

Annual cost of heat:

$$M_{\text{RB}} = V_{\text{gas,year}} \cdot 0.112 = 238708,14 \text{ m}^3 \cdot 0.112 \text{ euro/m}^3 = 26735.3 \text{ euro/ year}$$

5.3 The calculation of a roof boiler plant cost

Boilers “Viessmann” are used as a main boiler plant equipment. The boilers are equipped with gas burners “WEISHAUPT”. The heating system includes a system of an automatic correction of heat transfer media temperature, which depends on the outside temperature changes. Table 3 shows the cost of the equipment. The cost of equipment was converted from rubles to euros. 1 euro equals 45.06 rubles, in accordance with the currency rate of the Central Bank of the Russian Federation on 9 January 2014.

TABLE 3. Cost of equipment

| Name of equipment, types of work | Amount of equipment | Cost of equipment, euro |
|---|---------------------|-------------------------|
| Boiler "Viessmann". "Vitoplex-200", 200 kW | 1 | 4900,3 |
| Boiler "Viessmann". "Vitoplex-200", 270 kW | 1 | 6071,5 |
| Accessories for boilers | 1 set | 7878 |
| Antinoise prop under boilers | 2 | 370 |
| Gas burner "Weishaupt" WG30N/1 C | 2 set | 9320 |
| Solenoid valve and filter "Termobrest", thermal closing valve | 1 set | 7301,4 |
| Set of pump "Wilo" | 1 set | 11096,3 |
| Heat exchanger of HDW, 567 kW "RIDAN" | 2 | 2558,6 |
| Heat exchanger of heating system, 817 kW "RIDAN" | 2 | 7717,3 |
| Heat exchanger of ventilation, 1160 kW "RIDAN" | 2 | 9565,1 |
| Taps and fittings, Tecofi | 1 set | 14425 |
| Pipelines | 1 set | 6657,8 |
| Thermal insulation | 1 set | 1220,6 |
| Expendable materials | 1 set | 887,7 |
| Expansion tank "Reflex" | 1 set | 2108,3 |
| Gas contamination indicator | 1 | 670,6 |

| | | |
|--|-------|---------|
| Boiler automation system, control box | 1 set | 9321 |
| Control and measuring devices | 1 set | 2441,2 |
| Cable products | 1 set | 1664,5 |
| Dispatching and fire alarm system | 1 set | 2330,2 |
| Triple tube with heat insulated 2 m. | set | 10985,3 |
| Heating and ventilation system of boiler plant | 1 set | 6080 |
| Thermal energy metering units "VZLET" | 1 set | 8766,1 |
| Lighting | 1 set | 887,7 |
| Installation, adjustment of equipment, preparation for operation | | 71235,7 |
| Designing boiler plant | | 17088,3 |

The total cost of the boiler plant is 223548,5 euros

6 COMPARISION OF THE SYSTEMS

As it is known, the main factors affecting the efficiency of the heating system is the length of heating pipes, the amount of useful heat energy, and the amount of heat loss. Both of the selected heating systems are effective and both of them have their own advantages and disadvantages. The result of a comparison of the heating systems is shown in Table 4.

Individual heating system with roof gas boiler plant

The relatively short length of individual heating system networks allows to constantly maintain the desired temperature in the premises. This advantage can significantly reduce energy in heating and for laying pipes. The natural gas, which is not so expensive in Russia is used as a main fuel. This is the economic advantage of the individual heating system.

Placing the boiler plant on the roof has its benefits: there is no need for land allotment or constructing a separate building for the boiler plant; permanent free access to communications allows easily make technical inspection of the pipelines and system components and there is no need to install a high chimneys

The system is also rather simple in operation. The whole system is autonomous. The amount of a heat produced by each boiler can be adjusted in the range of 10% to 100% of the nominal capacity. On average, as the statistics show, the boiler plant operates with 70-75% of the nominal capacity in the heating season, and about 25% in summer. It allows for maintenance and repair work with a partial shutdown of the thermal capacity in any period.

On the downside, the roof boiler plant has several disadvantages too. The most important of these is the need to use the newest, modern equipment for the installation of roof boiler plant elements. This equipment is rather expensive. Additional funds are spent for the installation of automated control systems and regulation systems which continuously monitor parameters in the entire heating system of the shopping center. There are requirements for installing the gas boiler plant. First of all, the limitation by weight of the boiler, since it is the main source of mass. The weight of the boiler must be evenly distributed to all the bearing elements of the roof. That's why the best material for the manufacture of the heat exchangers is copper.

District heating system

District heating is a type of heating, which provides to consumers a stable supply by using several different heat boiler plants and the multifunctional network. One of the advantages of the system is its "flexible" manufacturing capabilities. District heating companies have many boiler plants with various technical and production capabilities. Thus, a district heating company may use different types of fuel to produce heat. This factor allows keeping a more flexible and stable price for heat than when one fuel is used for heating.

Nowadays in district heating modern technology is being increasingly used. For heat production, environmentally effective techniques are being increasingly used. The constant using of new technology reduces the harmful effects on the environment. The technical development also gives the opportunity to receive more heat from the combustion of fuel and improves the efficiency of the system. According to the requirements of the environment the district heating boiler plants have a high chimney. High chimneys improve the dissipation of emissions into the atmosphere. It helps to keep clean air in a city.

In addition, a district heating system is quite cost effective. There is the ability to use various cheap types of fuel, especially low-grade fuel. The total fuel consumption is also reduced through the use of heat produced as a waste of heat from electricity generation.

Currently, the main disadvantages of district heating are the high heat losses and a large percentage of the wearout of equipment. The high damageability of networks is the reason for accident situations. The most significant disadvantages of district heating are: large length of heat network, additional heat transfer losses, uncontrolled heat losses in the case of a pipeline break, complexity of the repairing and huge capital investments during the construction.

TABLE 4. The result of a comparison of the heating systems

| | District heating system | Individual heating system with roof boiler |
|------------------------------|--|---|
| Heat source | CHP plant | Roof boiler plant |
| Condition of network | old pipe from the heat source to the consumer | new pipelines |
| Location of heat source | separate building in relative proximity to the shopping center | on the roof of the shopping center |
| Heat transfer losses | The high heat losses because of large length of heat network | insignificant losses |
| Annual cost of heating | 52205.47 euros per year | 26735.3 euros per year |
| Automation of heating system | partially automated system | fully automated system |
| Land allotment necessity | yes | no |

7 CONCLUSION

The current bachelor thesis contains calculations, drawings and a results of the comparison of the systems. The heat sources for selected heating systems were picked up: CHP plant for a district heating system, and a roof gas boiler plant for an individual heating system. It was necessary to make the calculation of heat losses of the shopping

center. Using these results annual heating costs was calculated. The comparison has shown the efficiency of the selected heating systems and has identified goals for further development.

According to the results of the comparison, an individual heating system with roof gas boiler plant is a more cost-effective solution for heating the shopping center. This system is a widely used heating system which consists of the efficient modern heat source, automated control devices, and the pipeline from modern material. The individual heating system is also easy in installation and operation. This system is almost independent of urban heating networks, in order to avoid unnecessary interruptions of supply. However, this system depends on the gas supply of the city. Investigations of the Russian gas supply system in the recent years show that the system is working properly and without interruptions of gas supplies. Therefore the level of risk is reduced to a minimum due to the stability of the gas supply system. The individual heating system is much more economical than a district heating system. As a final conclusion it is possible to say an individual heating system is more suitable for the public building such in shopping center, and eventually will become one of the frequently used heating systems.

BIBLIOGRAPHY

1. James.E.Brumbaugh.HVAC.Fundamentals.vol.1.Heating Systems. Furnaces and Boilers. All New 4th.Edition. Wiley Publishing, Inc. 2004
2. Main type of heating system. SPRUT. [Основные виды систем отопления. СПРУТ.] WWW document. [www.http://sprut.msk.ru/otoplenie-chastnyh-domov-pod-klyuch/kak-obogret-dom/vidy-sistem-otopleniya/](http://sprut.msk.ru/otoplenie-chastnyh-domov-pod-klyuch/kak-obogret-dom/vidy-sistem-otopleniya/). Updated 27.10.2013. Referred 27.10.2013.
3. Ionin A.A. Heat supply. Moscow. Stroyizdat. 1982 [Ионин А. А. Тепло-снабжение. Москва. Стройиздат. 1982]
4. Building norms and regulations. Designing of DH. Moscow, 2003. [СНиП 41-02-2003 «Тепловые сети», Москва 2003]
5. Veli-Matti Makela. Bases for the recommendations for new norms in Russian district heating. Mikkeli University of Applied Sciences. 2008
6. Building norms and regulations. Boiler plants. Moscow, 1976. [СНиП II-35-76 «Котельные установки», Москва 1976]
7. Gasenergoinvest. Boiler plants. WWW document: <http://gazprice.ru/index.php?route=product/category&path=57>. Updated 21.11.2013. Referred 22.11.2013
8. Velikanov V.P., Kojurinchev A.M. Specifications for construction and operation of roof boiler plant on natural gas. Pamfilovs AME, Moscow, 1996. [Великанов В.П., Кожуринчев А.М. Технические условия по устройству и эксплуатации крышных котельных на природном газе. АКХ им. К. Д. Памфилова, Москва, 1996.]
9. ВТКdevelopment. U krasnogo mosta. WWW document: <http://ukrasnogomosta.ru/images/3.jpg>. Updated 01.11.2013 Referred 01.11.2013
10. TGK-1. Central CHP. WWW document: <http://www.tgc1.ru>. Updated 21.11.2013. Referred 21.11.2013
11. Viessmann. Gas boiler. WWW document: <http://www.viessmann.ru/ru/Mehrfamilienhaus/produkte.html> Updated 26.11.2013. Referred 22.11.2013
12. Building norms and regulations. Thermal protection of buildings. Moscow, 2003. [СНиП 23-02-2003 «Тепловая защита здания», Москва 2003]

13. Building norms and regulations. Construction climatology. Moscow, 1999. [СНиП 23-01-99 «Строительная климатология», Москва 1999]
14. Building norms and regulations. Design of thermal protection of buildings. Moscow, 2004. [СНиП 23-101-2004 «Проектирование тепловой защиты зданий», Москва 2004]
15. Building norms and regulations. Heating, Ventilation and Air Conditioning. Moscow, 1991. [СНиП 2.04.05-91 «Отопление вентиляция и кондиционирование», Москва 1991]
16. New tariffs. Saint-Petersburg tariffs. WWW document: <http://newtariffs.ru/all/tariff> Updated 4.12.2013. Referred 4.12.2013

APPENDIX 1(2).

The heat transfer coefficients

| Layers of enclosing structure | Volumetric weight, kg/m ³ | thickness of layer, m | heat transfer coefficient, W / m ² •°C | thermal resistance R, m ² •°C/W |
|--|--------------------------------------|-----------------------|---|--|
| 1 | 2 | 3 | 4 | 5 |
| External wall | | | | |
| wall along the axis A '(street facade - existing) | | | | |
| Clay brick | 1800 | 0,77 | 0,81 | 0,951 |
| Plaster | 1600 | 0,03 | 0,81 | 0,037 |
| Heat emission of internal surface | - | 1 | 8,7 | 0,115 |
| Heat emission of external surface | - | 1 | 23 | 0,043 |
| | | | | 1,146 |
| Coefficient of heat transfer | | | K= | 0,87 |
| wall along the axis 22 (street facade - existing) | | | | |
| Clay brick | 1800 | 0,77 | 0,81 | 0,951 |
| Plaster | 1600 | 0,03 | 0,81 | 0,037 |
| Heat emission of internal surface | - | 1 | 8,7 | 0,115 |
| Heat emission of external surface | - | 1 | 23 | 0,043 |
| | | | | 1,146 |
| Coefficient of heat transfer | | | K= | 0,87 |
| wall along the axis " Б*" | | | | |
| Gazobeton | 400 | 0,3 | 0,15 | 2 |
| Insulation "Rockwool VENT BATS" | 100 | 0,05 | 0,046 | 1,087 |
| Heat emission of internal surface | - | 1 | 8,7 | 0,115 |
| Heat emission of external surface | - | 1 | 23 | 0,043 |
| | | | | 3,245 |
| Coefficient of heat transfer | | | K= | 0,31 |
| wall along the axis 17 и "Б*" | | | | |
| Clay brick | 1800 | 0,77 | 0,81 | 0,951 |
| Plaster | 1600 | 0,03 | 0,81 | 0,037 |
| Heat emission of internal surface | - | 1 | 8,7 | 0,115 |
| Heat emission of external surface | - | 1 | 23 | 0,043 |
| | | | | 1,146 |
| Coefficient of heat transfer | | | K= | 0,87 |
| wall along the axis "И**"(internal) и "К**" | | | | |
| Clay brick | 1800 | 0,77 | 0,81 | 0,951 |
| Plaster | 1600 | 0,03 | 0,81 | 0,037 |
| Heat emission of internal surface | - | 1 | 8,7 | 0,115 |
| Heat emission of external surface | - | 1 | 23 | 0,043 |
| | | | | 1,146 |
| Coefficient of heat transfer | | | K= | 0,87 |

APPENDIX 1(2).

The heat transfer coefficients

| Window | | | | |
|--|------|------|-------|-------|
| double-glass | | | | 0,58 |
| Coefficient of heat transfer | | | K= | 1,72 |
| Roof | | | | |
| Insulation "Rockwool Roof BATS B" | 190 | 0,04 | 0,048 | 0,833 |
| Expanded polystyrene | | 0,05 | 0,06 | 0,833 |
| Insulation "Rockwool Roof BATS B" | 110 | 0,16 | 0,045 | 3,556 |
| Reinforced concrete slab | 2500 | 0,16 | 2,04 | 0,078 |
| Heat emission of internal surface | - | 1 | 8,7 | 0,115 |
| Heat emission of external surface | - | 1 | 23 | 0,043 |
| | | | | 5,459 |
| Coefficient of heat transfer | | | K= | 0,18 |
| Roof (in the area of the roof boiler plant) | | | | |
| Insulation "Rockwool Roof BATS B" | 190 | 0,04 | 0,048 | 0,833 |
| Expanded polystyrene | | 0,05 | 0,06 | 0,833 |
| Insulation "Rockwool Roof BATS H" | 110 | 0,04 | 0,045 | 0,889 |
| Heat emission of internal surface | - | 1 | 8,7 | 0,115 |
| Heat emission of external surface | - | 1 | 23 | 0,043 |
| | | | | 2,714 |
| Coefficient of heat transfer | | | K= | 0,37 |
| Covering over parking | | | | |
| Concrete paving slabs | | 0,08 | 1,86 | 0,043 |
| Sand | 1600 | 0,08 | 0,58 | 0,138 |
| lightweight concrete | 800 | 0,03 | 0,35 | 0,086 |
| Insulation – Penopleks 45 | 45 | 0,05 | 0,032 | 1,563 |
| Cement-sand grout | 1800 | 0,05 | 0,93 | 0,054 |
| Reinforced concrete slab | | 0,3 | 1,69 | 0,178 |
| Heat emission of internal surface | - | 1 | 8,7 | 0,115 |
| Heat emission of external surface | - | 1 | 23 | 0,043 |
| | | | | 2,219 |
| Coefficient of heat transfer | | | K= | 0,45 |
| Overlapping | | | | |
| Insulation | | 0,1 | 0,046 | 2,174 |
| Reinforced concrete slab | 2500 | 0,16 | 2,04 | 0,178 |
| Heat emission of internal surface | - | 1 | 8,7 | 0,115 |
| Heat emission of external surface | - | 1 | 23 | 0,043 |
| | | | | 2,482 |
| Coefficient of heat transfer | | | K= | 0,4 |

APPENDIX 2(1).

Heat loss calculation

| Name and number of space | Surface of enclosure | | Enclosure dimensions, m | | area of the enclosing structure | Design indoor air temperature, °C | Design outdoor air temperature, °C | Temperature difference, °C | Coefficient of additional heat loss | heat transfer coefficient | The main heat loss, W | The total heat loss, W | |
|--|----------------------------|------------------------------------|-------------------------|------|---------------------------------|-----------------------------------|------------------------------------|----------------------------|-------------------------------------|---------------------------|-----------------------|------------------------|-----------|
| | Designation | Orientation to the cardinal points | | | | | | | | | | | a |
| | | | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | |
| Basement (point -3,970) | | | | | | | | | | | | | |
| 001-Hall 1 | s11 | | 4,70 | 2,00 | 9,40 | 16 | -26 | 42 | 1 | 0,48 | 189,5 | 189,5 | |
| | s12 | | 4,70 | 2,00 | 9,40 | 16 | -26 | 42 | 1 | 0,23 | 90,8 | 90,8 | |
| | s13 | | 4,70 | 2,00 | 9,40 | 16 | -26 | 42 | 1 | 0,12 | 47,4 | 47,4 | |
| | s14 | | 4,70 | 8,85 | 41,60 | 16 | -26 | 42 | 1 | 0,07 | 122,3 | 122,3 | |
| | EW | SE | 4,70 | 1,70 | 7,99 | 16 | -26 | 42 | 1,05 | 0,873 | 292,8 | 307,5 | |
| | WD1 | SE | | | 3,16 | 16 | -26 | 42 | 1,05 | 0,852 | 113,0 | 118,7 | |
| | WD2 | SE | | | 2,44 | 16 | -26 | 42 | 1,05 | 0,852 | 87,3 | 91,6 | |
| | SUM | | | | | | | | | | | 943,1 | 967,7 |
| The total heat loss | | | | | | | | | | | | 968 | |
| 003-The space of reserve fire extinguishing | s11 | | 5,61 | 2,00 | 11,22 | 16 | -26 | 42 | 1 | 0,48 | 226,2 | 226,2 | |
| | s12 | | 5,61 | 2,00 | 11,22 | 16 | -26 | 42 | 1 | 0,23 | 108,4 | 108,4 | |
| | s13 | | 5,61 | 2,00 | 11,22 | 16 | -26 | 42 | 1 | 0,12 | 56,5 | 56,5 | |
| | s14 | | 5,61 | 3,72 | 20,87 | 16 | -26 | 42 | 1 | 0,07 | 61,4 | 61,4 | |
| | SUM | | | | | | | | | | | 452,5 | 452,5 |
| The total heat loss | | | | | | | | | | | | 452 | |
| with clockroom | s14 | | | | 20,95 | 16 | -26 | 42 | 1 | 0,07 | 61,6 | 61,6 | |
| | SUM | | | | | | | | | | | 61,6 | 61,6 |
| | The total heat loss | | | | | | | | | | | | 62 |
| for cleaning | s14 | | | | 2,19 | 16 | -26 | 42 | 1 | 0,07 | 6,4 | 6,4 | |
| | SUM | | | | | | | | | | | 6,4 | 6,4 |
| | The total heat loss | | | | | | | | | | | | 6 |
| 006-WC | s14 | | | | 5,83 | 16 | -26 | 42 | 1 | 0,07 | 17,1 | 17,1 | |
| | SUM | | | | | | | | | | | 17,1 | 17,1 |
| | The total heat loss | | | | | | | | | | | | 17 |
| 007-WC | s14 | | | | 6,00 | 16 | -26 | 42 | 1 | 0,07 | 17,6 | 17,6 | |
| | SUM | | | | | | | | | | | 17,6 | 17,6 |
| | The total heat loss | | | | | | | | | | | | 18 |
| 008-Space for café | s11 | | | | 53,00 | 22 | -26 | 48 | 1 | 0,48 | 1221,1 | 1221,1 | |
| | s12 | | | | 67,10 | 22 | -26 | 48 | 1 | 0,23 | 740,8 | 740,8 | |
| | s13 | | | | 65,00 | 22 | -26 | 48 | 1 | 0,12 | 374,4 | 374,4 | |
| | s14 | | | | 264,00 | 22 | -26 | 48 | 1 | 0,07 | 887,0 | 887,0 | |

APPENDIX 2(2).

Heat loss calculation

| | | | | | | | | | | | | | |
|---------------------------|----------------------------|----|------|-------|-------|----|-----|----|------|-------|-------|--------|-------------|
| | EW1 | SE | 4,70 | 1,30 | 6,11 | 22 | -26 | 48 | 1,05 | 0,873 | 255,9 | 268,7 | |
| | EW2 | NE | 4,70 | 1,30 | 6,11 | 22 | -26 | 48 | 1,15 | 0,873 | 255,9 | 294,3 | |
| | WD1 | SE | | | 7,32 | 22 | -26 | 48 | 1,05 | 0,852 | 299,2 | 314,2 | |
| | WD2 | NE | | | 3,16 | 22 | -26 | 48 | 1,15 | 0,852 | 129,2 | 148,5 | |
| | SUM | | | | | | | | | | | 4163,5 | 4249,1 |
| | The total heat loss | | | | | | | | | | | | 4249 |
| 009/1- Staircase | sl4 | | | | 13,28 | 16 | -26 | 42 | 1 | 0,07 | 39,0 | 39,0 | |
| | SUM | | | | | | | | | | | 39,0 | 39,0 |
| | The total heat loss | | | | | | | | | | | | 39 |
| 009/2- Tambou r 4 | sl4 | | | | 5,09 | 16 | -26 | 42 | 1 | 0,07 | 15,0 | 15,0 | |
| | SUM | | | | | | | | | | | 15,0 | 15,0 |
| | The total heat loss | | | | | | | | | | | | 15 |
| 010- Space for café | sl4 | | | | 12,10 | 16 | -26 | 42 | 1 | 0,07 | 35,6 | 35,6 | |
| | SUM | | | | | | | | | | | 35,6 | 35,6 |
| | The total heat loss | | | | | | | | | | | | 36 |
| 011-Hot shop café | sl4 | | | | 33,29 | 16 | -26 | 42 | 1 | 0,07 | 97,9 | 97,9 | |
| | SUM | | | | | | | | | | | 97,9 | 97,9 |
| | The total heat loss | | | | | | | | | | | | 98 |
| 012-Cold shop café | sl4 | | | | 15,44 | 16 | -26 | 42 | 1 | 0,07 | 45,4 | 45,4 | |
| | SUM | | | | | | | | | | | 45,4 | 45,4 |
| | The total heat loss | | | | | | | | | | | | 45 |
| 013- Space for café | sl4 | | | | 12,52 | 16 | -26 | 42 | 1 | 0,07 | 36,8 | 36,8 | |
| | SUM | | | | | | | | | | | 36,8 | 36,8 |
| | The total heat loss | | | | | | | | | | | | 37 |
| Washing room of | sl4 | | | | 17,26 | 16 | -26 | 42 | 1 | 0,07 | 50,7 | 50,7 | |
| | SUM | | | | | | | | | | | 50,7 | 50,7 |
| | The total heat loss | | | | | | | | | | | | 51 |
| 015- storage room | sl4 | | | | 6,96 | 16 | -26 | 42 | 1 | 0,07 | 20,5 | 20,5 | |
| | SUM | | | | | | | | | | | 20,5 | 20,5 |
| | The total heat loss | | | | | | | | | | | | 20 |
| 016-Café staff room | sl4 | | | | 4,31 | 16 | -26 | 42 | 1 | 0,07 | 12,7 | 12,7 | |
| | SUM | | | | | | | | | | | 12,7 | 12,7 |
| | The total heat loss | | | | | | | | | | | | 13 |
| 017- storage room | sl4 | | | | 11,88 | 16 | -26 | 42 | 1 | 0,07 | 34,9 | 34,9 | |
| | SUM | | | | | | | | | | | 34,9 | 34,9 |
| | The total heat loss | | | | | | | | | | | | 35 |
| 018- storage room | sl4 | | | | 11,88 | 16 | -26 | 42 | 1 | 0,07 | 34,9 | 34,9 | |
| | SUM | | | | | | | | | | | 34,9 | 34,9 |
| | The total heat loss | | | | | | | | | | | | 35 |
| 019-Hall (1) | sl1 | | | 23,32 | 23,32 | 16 | -26 | 42 | 1 | 0,48 | 470,1 | 470,1 | |
| | sl2 | | | 32,28 | 32,28 | 16 | -26 | 42 | 1 | 0,23 | 311,8 | 311,8 | |
| | sl3 | | | 17,45 | 13,88 | 16 | -26 | 42 | 1 | 0,12 | 70,0 | 70,0 | |
| | sl4 | | | 69,86 | 72,73 | 16 | -26 | 42 | 1 | 0,07 | 213,8 | 213,8 | |

APPENDIX 2(3).

Heat loss calculation

| | | | | | | | | | | | | | |
|---------------------|-----|----|--|--|-------|----|-----|----|---|----------------------------|----------------------------|-------------|-------------|
| | | | | | | | | | | SUM | 1065,7 | 1065,7 | |
| | | | | | | | | | | The total heat loss | | 1066 | |
| Storage room of | sl4 | | | | 13,96 | 16 | -26 | 42 | 1 | 0,07 | 41,0 | 41,0 | |
| | | | | | | | | | | SUM | 41,0 | 41,0 | |
| | | | | | | | | | | The total heat loss | | 41 | |
| 021- Storage room | sl4 | | | | 14,70 | 16 | -26 | 42 | 1 | 0,07 | 43,2 | 43,2 | |
| | | | | | | | | | | SUM | 43,2 | 43,2 | |
| | | | | | | | | | | The total heat loss | | 43 | |
| 022- Storage room | sl4 | | | | 11,88 | 16 | -26 | 42 | 1 | 0,07 | 34,9 | 34,9 | |
| | | | | | | | | | | SUM | 34,9 | 34,9 | |
| | | | | | | | | | | The total heat loss | | 35 | |
| Storage room of | sl4 | | | | 34,68 | 16 | -26 | 42 | 1 | 0,07 | 102,0 | 102,0 | |
| | | | | | | | | | | SUM | 102,0 | 102,0 | |
| | | | | | | | | | | The total heat loss | | 102 | |
| Storage room of | sl4 | | | | 45,65 | 16 | -26 | 42 | 1 | 0,07 | 134,2 | 134,2 | |
| | | | | | | | | | | SUM | 134,2 | 134,2 | |
| | | | | | | | | | | The total heat loss | | 134 | |
| Washing room of | sl4 | | | | 15,54 | 16 | -26 | 42 | 1 | 0,07 | 45,7 | 45,7 | |
| | | | | | | | | | | SUM | 45,7 | 45,7 | |
| | | | | | | | | | | The total heat loss | | 46 | |
| 025- Storage room | sl4 | | | | 20,90 | 16 | -26 | 42 | 1 | 0,07 | 61,4 | 61,4 | |
| | | | | | | | | | | SUM | 61,4 | 61,4 | |
| | | | | | | | | | | The total heat loss | | 61 | |
| 026-Hall (2) | sl1 | | | | 27,62 | 16 | -26 | 42 | 1 | 0,48 | 556,8 | 556,8 | |
| | sl2 | | | | 6,56 | 16 | -26 | 42 | 1 | 0,23 | 63,4 | 63,4 | |
| | sl3 | | | | 2,24 | 16 | -26 | 42 | 1 | 0,12 | 11,3 | 11,3 | |
| | sl4 | | | | 0,00 | 16 | -26 | 42 | 1 | 0,07 | 0,0 | 0,0 | |
| | EW | SW | | | 31,89 | 16 | -26 | 42 | 1 | 0,873 | 1168,7 | 1168,7 | |
| | WD1 | SW | | | 2,30 | 16 | -26 | 42 | 1 | 0,852 | 82,3 | 82,3 | |
| | D | SW | | | 2,28 | 16 | -26 | 42 | 1 | 0 | 0,0 | 0,0 | |
| | | | | | | | | | | | SUM | 1882,5 | 1882,5 |
| | | | | | | | | | | | The total heat loss | | 1882 |
| 027- Tambou r.1 | sl4 | | | | 4,80 | 16 | -26 | 42 | 1 | 0,07 | 14,1 | 14,1 | |
| | | | | | | | | | | SUM | 14,1 | 14,1 | |
| | | | | | | | | | | The total heat loss | | 14 | |
| 028- Tambou r.2 | sl4 | | | | 8,05 | 16 | -26 | 42 | 1 | 0,07 | 23,7 | 23,7 | |
| | | | | | | | | | | SUM | 23,7 | 23,7 | |
| | | | | | | | | | | The total heat loss | | 24 | |
| 029- Staircase JL-8 | sl4 | | | | 13,05 | 16 | -26 | 42 | 1 | 0,07 | 38,4 | 38,4 | |
| | | | | | | | | | | SUM | 38,4 | 38,4 | |
| | | | | | | | | | | The total heat loss | | 38 | |
| 030- Staff room | sl4 | | | | 13,10 | 16 | -26 | 42 | 1 | 0,07 | 38,5 | 38,5 | |
| | | | | | | | | | | SUM | 38,5 | 38,5 | |

APPENDIX 2(4).

Heat loss calculation

| | | | | | | | | | | | | |
|----------------------------|----------------------------|----|------|------|--------|----|-----|----|------|-------|-------------|------------|
| 031-Staff room | The total heat loss | | | | | | | | | | | 39 |
| | sl4 | | | | 62,36 | 16 | -26 | 42 | 1 | 0,07 | 183,3 | 183,3 |
| | SUM | | | | | | | | | | 183,3 | 183,3 |
| 032-Staff room | The total heat loss | | | | | | | | | | | 183 |
| | sl4 | | | | 99,46 | 16 | -26 | 42 | 1 | 0,07 | 292,4 | 292,4 |
| | SUM | | | | | | | | | | 292,4 | 292,4 |
| 033-Hall (3) | The total heat loss | | | | | | | | | | | 292 |
| | sl1 | | | | 44,42 | 16 | -26 | 42 | 1 | 0,48 | 895,5 | 895,5 |
| | sl2 | | | | 40,52 | 16 | -26 | 42 | 1 | 0,23 | 391,4 | 391,4 |
| | sl3 | | | | 36,14 | 16 | -26 | 42 | 1 | 0,12 | 182,1 | 182,1 |
| | sl4 | | | | 142,17 | 16 | -26 | 42 | 1 | 0,07 | 418,0 | 418,0 |
| | EW1 | NE | | | 14,10 | 16 | -26 | 42 | 1,15 | 0,873 | 516,8 | 594,3 |
| | WD1 | NE | | | 6,72 | 16 | -26 | 42 | 1,15 | 0,852 | 240,3 | 276,4 |
| | WD2 | NE | | | 3,16 | 16 | -26 | 42 | 1,15 | 0,852 | 113,0 | 130,0 |
| | EW2 | SW | 4,89 | 3,24 | 15,84 | 16 | -26 | 42 | 1 | 0,873 | 580,7 | 580,7 |
| | D | SW | | | 2,28 | 16 | -26 | 42 | 1 | 1,553 | 148,7 | 148,7 |
| | SUM | | | | | | | | | | 3486,5 | 3617,1 |
| The total heat loss | | | | | | | | | | | 3617 | |
| 034-Security room | sl1 | | | | 3,70 | 18 | -26 | 44 | 1 | 0,48 | 78,1 | 78,1 |
| | sl2 | | | | 0,79 | 18 | -26 | 44 | 1 | 0,23 | 8,0 | 8,0 |
| | sl3 | | | | 0,00 | 18 | -26 | 44 | 1 | 0,12 | 0,0 | 0,0 |
| | sl4 | | | | 0,00 | 18 | -26 | 44 | 1 | 0,07 | 0,0 | 0,0 |
| | EW | SW | 1,00 | 3,24 | 3,24 | 18 | -26 | 44 | 1 | 0,873 | 124,4 | 124,4 |
| | SUM | | | | | | | | | | 210,5 | 210,5 |
| The total heat loss | | | | | | | | | | | 211 | |
| 035-WC | sl4 | | | | 7,20 | 16 | -26 | 42 | 1 | 0,07 | 21,2 | 21,2 |
| | SUM | | | | | | | | | | 21,2 | 21,2 |
| | The total heat loss | | | | | | | | | | | 21 |
| 036-WC | sl4 | | | | 7,20 | 16 | -26 | 42 | 1 | 0,07 | 21,2 | 21,2 |
| | SUM | | | | | | | | | | 21,2 | 21,2 |
| | The total heat loss | | | | | | | | | | | 21 |
| 037-Utility room | sl4 | | | | 5,10 | 16 | -26 | 42 | 1 | 0,07 | 15,0 | 15,0 |
| | SUM | | | | | | | | | | 15,0 | 15,0 |
| | The total heat loss | | | | | | | | | | | 15 |
| 038-Utility room | sl1 | | | | 3,40 | 16 | -26 | 42 | 1 | 0,48 | 68,5 | 68,5 |
| | sl2 | | | | 1,87 | 16 | -26 | 42 | 1 | 0,23 | 18,1 | 18,1 |
| | sl3 | | | | 0,00 | 16 | -26 | 42 | 1 | 0,12 | 0,0 | 0,0 |
| | sl4 | | | | 0,00 | 16 | -26 | 42 | 1 | 0,07 | 0,0 | 0,0 |
| | EW | SW | | | 3,24 | 16 | -26 | 42 | 1,05 | 0,873 | 118,7 | 124,7 |
| | SUM | | | | | | | | | | 205,4 | 211,3 |
| The total heat loss | | | | | | | | | | | 211 | |
| 039-Hall (3) | sl1 | | | | 19,83 | 16 | -26 | 42 | 1 | 0,48 | 399,8 | 399,8 |
| | EW | SW | 5,70 | 3,24 | 18,47 | 16 | -26 | 42 | 1,05 | 0,873 | 676,8 | 710,7 |

APPENDIX 2(5).

Heat loss calculation

| | | | | | | | | | | | | |
|---------------------------------------|----------------------------|--|-------|------|-------|----|-----|----|------|-------|--------|-------------|
| | D | | | | 6,26 | 16 | -26 | 42 | 1,05 | 1,553 | 408,3 | 428,7 |
| | SUM | | | | | | | | | | 1484,9 | 1539,2 |
| | The total heat loss | | | | | | | | | | | 1539 |
| 040- Utility room | sl4 | | | | 11,36 | 16 | -26 | 42 | 1 | 0,07 | 33,4 | 33,4 |
| | SUM | | | | | | | | | | 33,4 | 33,4 |
| | The total heat loss | | | | | | | | | | | 33 |
| 041-Hall (4) | sl1 | | | | 4,00 | 15 | -26 | 41 | 1 | 0,48 | 78,7 | 78,7 |
| | sl2 | | | | 4,00 | 15 | -26 | 41 | 1 | 0,23 | 37,7 | 37,7 |
| | sl3 | | | | 4,00 | 15 | -26 | 41 | 1 | 0,12 | 19,7 | 19,7 |
| | sl4 | | | | 7,88 | 15 | -26 | 41 | 1 | 0,07 | 22,6 | 22,6 |
| | SUM | | | | | | | | | | 158,7 | 158,7 |
| | The total heat loss | | | | | | | | | | | 159 |
| 042-Utility room | sl1 | | | | 19,94 | 15 | -26 | 41 | 1 | 0,48 | 392,4 | 392,4 |
| | sl2 | | | | 20,21 | 15 | -26 | 41 | 1 | 0,23 | 190,6 | 190,6 |
| | sl3 | | | | 12,90 | 15 | -26 | 41 | 1 | 0,12 | 63,5 | 63,5 |
| | sl4 | | | | 4,85 | 15 | -26 | 41 | 1 | 0,07 | 13,9 | 13,9 |
| | SUM | | | | | | | | | | 660,4 | 660,4 |
| | The total heat loss | | | | | | | | | | | 660 |
| 043-Room for cleaning equipment | sl1 | | | | 5,28 | 16 | -26 | 42 | 1 | 0,48 | 106,4 | 106,4 |
| | sl2 | | | | 5,28 | 16 | -26 | 42 | 1 | 0,23 | 51,0 | 51,0 |
| | sl3 | | | | 5,28 | 16 | -26 | 42 | 1 | 0,12 | 26,6 | 26,6 |
| | sl4 | | | | 3,75 | 16 | -26 | 42 | 1 | 0,07 | 11,0 | 11,0 |
| | SUM | | | | | | | | | | 195,1 | 195,1 |
| | The total heat loss | | | | | | | | | | | 195 |
| 044- Elevator tambour | sl4 | | | | 5,12 | 16 | -26 | 42 | 1 | 0,07 | 15,1 | 15,1 |
| | SUM | | | | | | | | | | 15,1 | 15,1 |
| | The total heat loss | | | | | | | | | | | 15 |
| 045-Elevator tambour | sl1 | | 10,68 | 2,00 | 21,36 | 16 | -26 | 42 | 1 | 0,48 | 430,6 | 430,6 |
| | sl2 | | 10,68 | 2,00 | 21,36 | 16 | -26 | 42 | 1 | 0,23 | 206,3 | 206,3 |
| | sl3 | | 10,68 | 2,00 | 21,36 | 16 | -26 | 42 | 1 | 0,12 | 107,7 | 107,7 |
| | sl4 | | 10,86 | 1,52 | 16,51 | 16 | -26 | 42 | 1 | 0,07 | 48,5 | 48,5 |
| | SUM | | | | | | | | | | 793,1 | 793,1 |
| | The total heat loss | | | | | | | | | | | 793 |
| 046- storage | sl4 | | | | 25,00 | 16 | -26 | 42 | 1 | 0,07 | 73,5 | 73,5 |
| | SUM | | | | | | | | | | 73,5 | 73,5 |
| | The total heat loss | | | | | | | | | | | 74 |
| 047- Storage | sl4 | | | | 10,70 | 16 | -26 | 42 | 1 | 0,07 | 31,5 | 31,5 |
| | SUM | | | | | | | | | | 31,5 | 31,5 |
| | The total heat loss | | | | | | | | | | | 31 |
| 048-staff room | sl4 | | | | 14,50 | 16 | -26 | 42 | 1 | 0,07 | 42,6 | 42,6 |
| | SUM | | | | | | | | | | 42,6 | 42,6 |
| | The total heat loss | | | | | | | | | | | 43 |
| sta ff ro | sl4 | | | | 9,90 | 16 | -26 | 42 | 1 | 0,07 | 29,1 | 29,1 |

APPENDIX 2(6).

Heat loss calculation

| | | | | | | | | | | | | | |
|--------------------|-----|--|-------|------|-------|----|-----|----|---|----------------------------|----------------------------|-----------|------------|
| | | | | | | | | | | SUM | 29,1 | 29,1 | |
| | | | | | | | | | | The total heat loss | | 29 | |
| 050-staff room | sl4 | | | | 15,39 | 16 | -26 | 42 | 1 | 0,07 | 45,2 | 45,2 | |
| | | | | | | | | | | SUM | 45,2 | 45,2 | |
| | | | | | | | | | | The total heat loss | | 45 | |
| 051-WC | sl4 | | | | 1,65 | 16 | -26 | 42 | 1 | 0,07 | 4,9 | 4,9 | |
| | | | | | | | | | | SUM | 4,9 | 4,9 | |
| | | | | | | | | | | The total heat loss | | 5 | |
| 052-WC | sl4 | | | | 1,65 | 16 | -26 | 42 | 1 | 0,07 | 4,9 | 4,9 | |
| | | | | | | | | | | SUM | 4,9 | 4,9 | |
| | | | | | | | | | | The total heat loss | | 5 | |
| 053-clock room | sl4 | | | | 15,50 | 16 | -26 | 42 | 1 | 0,07 | 45,6 | 45,6 | |
| | | | | | | | | | | SUM | 45,6 | 45,6 | |
| | | | | | | | | | | The total heat loss | | 46 | |
| 054-clock room | sl4 | | | | 11,63 | 16 | -26 | 42 | 1 | 0,07 | 34,2 | 34,2 | |
| | | | | | | | | | | SUM | 34,2 | 34,2 | |
| | | | | | | | | | | The total heat loss | | 34 | |
| 055-staff room | sl4 | | | | 11,62 | 16 | -26 | 42 | 1 | 0,07 | 34,2 | 34,2 | |
| | | | | | | | | | | SUM | 34,2 | 34,2 | |
| | | | | | | | | | | The total heat loss | | 34 | |
| 056-Tambour r.3 | sl4 | | | | 7,22 | 16 | -26 | 42 | 1 | 0,07 | 21,2 | 21,2 | |
| | | | | | | | | | | SUM | 21,2 | 21,2 | |
| | | | | | | | | | | The total heat loss | | 21 | |
| 057-Staircase J19A | sl4 | | | | 11,96 | 16 | -26 | 42 | 1 | 0,07 | 35,2 | 35,2 | |
| | | | | | | | | | | Сумма | 35,2 | 35,2 | |
| | | | | | | | | | | Общие теплопотери | | 35 | |
| 058-Staircase | sl4 | | | | 11,46 | 16 | -26 | 42 | 1 | 0,07 | 33,7 | 33,7 | |
| | | | | | | | | | | SUM | 33,7 | 33,7 | |
| | | | | | | | | | | The total heat loss | | 34 | |
| 059-Utility room | sl1 | | 2,95 | 2,00 | 5,90 | 16 | -26 | 42 | 1 | 0,48 | 118,9 | 118,9 | |
| | sl2 | | 2,95 | 2,00 | 5,90 | 16 | -26 | 42 | 1 | 0,23 | 57,0 | 57,0 | |
| | sl3 | | 2,95 | 2,00 | 5,90 | 16 | -26 | 42 | 1 | 0,12 | 29,7 | 29,7 | |
| | sl4 | | 2,95 | 0,48 | 1,42 | 16 | -26 | 42 | 1 | 0,07 | 4,2 | 4,2 | |
| | | | | | | | | | | | SUM | 209,8 | 209,8 |
| | | | | | | | | | | | The total heat loss | | 210 |
| 060-Utility room | sl1 | | | | 20,00 | 16 | -26 | 42 | 1 | 0,48 | 403,2 | 403,2 | |
| | sl2 | | | | 19,42 | 16 | -26 | 42 | 1 | 0,23 | 187,6 | 187,6 | |
| | sl3 | | | | 13,88 | 16 | -26 | 42 | 1 | 0,12 | 70,0 | 70,0 | |
| | sl4 | | | | 0,00 | 16 | -26 | 42 | 1 | 0,07 | 0,0 | 0,0 | |
| | | | | | | | | | | | SUM | 660,8 | 660,8 |
| | | | | | | | | | | | The total heat loss | | 661 |
| Technical room | sl1 | | 12,71 | 2,00 | 25,42 | 16 | -26 | 42 | 1 | 0,48 | 512,5 | 512,5 | |
| | sl2 | | 12,71 | 2,00 | 25,42 | 16 | -26 | 42 | 1 | 0,23 | 245,6 | 245,6 | |

APPENDIX 2(7).

Heat loss calculation

| | | | | | | | | | | | | |
|---|----------------------------|----|-------|------|-------|----|-----|----|------|--------|--------|-------------|
| | sl3 | | 12,71 | 2,00 | 25,42 | 16 | -26 | 42 | 1 | 0,12 | 128,1 | 128,1 |
| | sl4 | | 12,71 | 3,14 | 39,91 | 16 | -26 | 42 | 1 | 0,07 | 117,3 | 117,3 |
| | SUM | | | | | | | | | | 1003,5 | 1003,5 |
| | The total heat loss | | | | | | | | | | | 1003 |
| The sum of heat loss of basement = 20340 W | | | | | | | | | | | | |
| First floor | | | | | | | | | | | | |
| 102 | EW | SE | 2,26 | 4,71 | 10,64 | 16 | -26 | 42 | 1,05 | 0,873 | 390,1 | 409,6 |
| | WD | SE | 2,26 | 4,03 | 9,11 | 16 | -26 | 42 | 1,05 | 0,852 | 325,7 | 342,0 |
| | | | | | | | | | | | | |
| | SUM | | | | | | | | | | 715,9 | 751,6 |
| | The total heat loss | | | | | | | | | | | 752 |
| 103 | EW | SE | 2,90 | 4,78 | 13,86 | 16 | -26 | 42 | 1,05 | 0,873 | 508,0 | 533,4 |
| | WD | SE | 2,90 | 4,03 | 11,69 | 16 | -26 | 42 | 1,05 | 0,852 | 418,0 | 438,9 |
| | | | | | | | | | | | | |
| | SUM | | | | | | | | | | 926,0 | 972,3 |
| | The total heat loss | | | | | | | | | | | 972 |
| 105 | EW1 | NE | 5,40 | 4,78 | 25,81 | 16 | -26 | 42 | 1,1 | 0,873 | 946,0 | 1040,6 |
| | EW2 | SW | 4,57 | 4,78 | 21,84 | 16 | -26 | 42 | 1 | 0,873 | 800,6 | 800,6 |
| | EW3 | SW | 5,40 | 4,78 | 25,81 | 16 | -26 | 42 | 1 | 0,873 | 946,0 | 946,0 |
| | EW4 | SW | 4,97 | 4,78 | 23,76 | 16 | -26 | 42 | 1 | 0,873 | 870,7 | 870,7 |
| | EW5 | NE | 2,68 | 4,78 | 12,81 | 16 | -26 | 42 | 1,1 | 0,873 | 469,5 | 516,4 |
| | WD1 | NE | 4,35 | 3,98 | 17,32 | 16 | -26 | 42 | 1,1 | 0,852 | 619,4 | 681,4 |
| | WD2 | SW | 3,40 | 3,98 | 13,53 | 16 | -26 | 42 | 1 | 0,852 | 484,0 | 484,0 |
| | WD3 | SW | 2,68 | 3,98 | 10,67 | 16 | -26 | 42 | 1 | 0,852 | 381,5 | 381,5 |
| | WD4 | NE | 2,08 | 3,43 | 7,13 | 16 | -26 | 42 | 1,1 | 0,852 | 255,2 | 280,7 |
| | | | | | | | | | | | | |
| SUM | | | | | | | | | | 5772,8 | 6001,8 | |
| | The total heat loss | | | | | | | | | | | 6002 |
| 106 | EW | SE | 19,42 | 4,78 | 92,83 | 20 | -26 | 46 | 1,05 | 0,873 | 3726,1 | 3912,4 |
| | WD1 | SE | 4,50 | 3,98 | 53,73 | 20 | -26 | 46 | 1,05 | 0,852 | 2104,6 | 2209,9 |
| | WD2 | SE | 2,24 | 3,98 | 8,92 | 20 | -26 | 46 | 1,05 | 0,852 | 349,2 | 366,7 |
| | SUM | | | | | | | | | | 6179,9 | 6488,9 |
| | The total heat loss | | | | | | | | | | | 6489 |
| 109 | EW | SE | 2,27 | 4,78 | 10,85 | 16 | -26 | 42 | 1,05 | 0,873 | 397,7 | 417,5 |
| | WD | SE | 2,27 | 3,98 | 9,03 | 16 | -26 | 42 | 1,05 | 0,852 | 323,1 | 339,3 |
| | | | | | | | | | | | | |
| | SUM | | | | | | | | | | 720,8 | 756,8 |
| | The total heat loss | | | | | | | | | | | 757 |
| 110 | EW1 | E | 6,06 | 4,78 | 28,97 | 16 | -26 | 42 | 1,15 | 0,873 | 1061,6 | 1220,9 |
| | EW2 | SE | 0,80 | 4,78 | 3,82 | 16 | -26 | 42 | 1,15 | 0,873 | 140,1 | 161,2 |
| | EW3 | NE | 0,80 | 5,24 | 4,19 | 16 | -26 | 42 | 1,15 | 0,873 | 153,6 | 176,7 |
| | WD | | | | 38,78 | 16 | -26 | 42 | 1 | 0,852 | 1387,0 | 1387,0 |
| | SUM | | | | | | | | | | 2742,3 | 2945,6 |

APPENDIX 2(9).

Heat loss calculation

| | | | | | | | | | | | | |
|---|-----|----|-------|------|-------|----|-----|----|------|----------------------------|--------|-------------|
| | | | | | | | | | | SUM | 478,3 | 526,1 |
| | | | | | | | | | | The total heat loss | | 526 |
| 125 | EW | NW | 10,60 | 4,78 | 50,67 | 16 | -26 | 42 | 1,1 | 0,873 | 1856,9 | 2042,6 |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | SUM | 1856,9 | 2042,6 |
| | | | | | | | | | | The total heat loss | | 2043 |
| 126 | EW | NW | 5,40 | 4,78 | 25,81 | 16 | -26 | 42 | 1,1 | 0,873 | 946,0 | 1040,6 |
| | KP | | | | 21,60 | 16 | -26 | 42 | 1 | 0,209 | 189,6 | 189,6 |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | SUM | 1135,6 | 1230,2 |
| | | | | | | | | | | The total heat loss | | 1230 |
| 128 | EW | NW | 6,70 | 4,71 | 31,56 | 16 | -26 | 42 | 1,1 | 0,873 | 1156,5 | 1272,2 |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | SUM | 1156,5 | 1272,2 |
| | | | | | | | | | | The total heat loss | | 1272 |
| 131 | EW1 | NW | 2,70 | 4,67 | 12,61 | 5 | -26 | 31 | 1,15 | 0,873 | 341,1 | 392,2 |
| | EW2 | NE | 4,30 | 4,67 | 11,66 | 5 | -26 | 31 | 1,15 | 0,873 | 315,3 | 362,6 |
| | WD | NE | | | 2,00 | 5 | -26 | 31 | 1,15 | 0,852 | 52,8 | 60,7 |
| | D | NE | 3,51 | 2,40 | 8,42 | 5 | -26 | 31 | 2,41 | 2,105 | 549,7 | 1324,8 |
| | | | | | | | | | | | | |
| | | | | | | | | | | SUM | 1258,9 | 2140,4 |
| | | | | | | | | | | The total heat loss | | 2140 |
| The sum of heat loss of first floor =43930 W | | | | | | | | | | | | |
| Second floor | | | | | | | | | | | | |
| 203-hall | EW1 | SW | 5,42 | 4,24 | 22,98 | 18 | -26 | 44 | 1,05 | 0,873 | 882,3 | 926,5 |
| | EW2 | NW | 5,40 | 4,24 | 22,90 | 18 | -26 | 44 | 1,1 | 0,873 | 879,1 | 967,0 |
| | WD1 | SW | | | 6,36 | 18 | -26 | 44 | 1,05 | 0,852 | 238,3 | 250,2 |
| | WD2 | NW | | | 7,75 | 18 | -26 | 44 | 1,1 | 0,852 | 290,4 | 319,4 |
| | | | | | | | | | | | | |
| | | | | | | | | | | SUM | 2290,1 | 2463,1 |
| | | | | | | | | | | The total heat loss | | 2463 |
| 204 | EW | SE | 6,84 | 4,77 | 32,63 | 18 | -26 | 44 | 1,05 | 0,873 | 1252,7 | 1315,3 |
| | WD | SE | | | 18,26 | 18 | -26 | 44 | 1,05 | 0,852 | 684,2 | 718,4 |
| | | | | | | | | | | | | |
| | | | | | | | | | | SUM | 1936,8 | 2033,7 |
| | | | | | | | | | | The total heat loss | | 2034 |
| 205 | EW | SE | 6,84 | 4,77 | 32,63 | 18 | -26 | 44 | 1,05 | 0,873 | 1252,7 | 1315,3 |
| | WD | SE | | | 29,80 | 18 | -26 | 44 | 1,05 | 0,852 | 1116,5 | 1172,4 |
| | | | | | | | | | | | | |
| | | | | | | | | | | SUM | 2369,2 | 2487,7 |
| | | | | | | | | | | The total heat loss | | 2488 |
| 206 | EW | SE | 11,82 | 4,77 | 56,38 | 18 | -26 | 44 | 1,05 | 0,873 | 2164,7 | 2273,0 |
| | WD | SE | | | 29,80 | 18 | -26 | 44 | 1,05 | 0,852 | 1116,5 | 1172,4 |
| | | | | | | | | | | | | |
| | | | | | | | | | | SUM | 3281,3 | 3445,3 |
| | | | | | | | | | | The total heat loss | | 3445 |

APPENDIX 2(10).

Heat loss calculation

| | | | | | | | | | | | | | |
|----------------------------|----------------------------|----|-------|------|-------|----|-----|----|------|-------|--------|--------|-------------|
| 207 | EW1 | SE | 5,92 | 4,77 | 28,24 | 18 | -26 | 44 | 1,15 | 0,873 | 1084,2 | 1246,8 | |
| | EW2 | E | 6,00 | 4,77 | 28,62 | 18 | -26 | 44 | 1,15 | 0,873 | 1098,8 | 1263,7 | |
| | EW3 | NE | 5,35 | 4,77 | 25,52 | 18 | -26 | 44 | 1,15 | 0,873 | 979,8 | 1126,8 | |
| | WD1 | SE | | | 14,90 | 18 | -26 | 44 | 1,15 | 0,852 | 558,3 | 642,0 | |
| | WD2 | E | | | 13,20 | 18 | -26 | 44 | 1,15 | 0,852 | 494,6 | 568,8 | |
| | WD3 | NE | | | 14,15 | 18 | -26 | 44 | 1,15 | 0,852 | 530,2 | 609,7 | |
| | SUM | | | | | | | | | | | 4745,9 | 5457,7 |
| The total heat loss | | | | | | | | | | | | | 5458 |
| 208 | EW | NE | 11,50 | 4,77 | 54,86 | 18 | -26 | 44 | 1,1 | 0,873 | 2106,1 | 2316,7 | |
| | WD | NE | | | 28,30 | 18 | -26 | 44 | 1,1 | 0,852 | 1060,3 | 1166,4 | |
| | SUM | | | | | | | | | | | 3166,5 | 3483,1 |
| | The total heat loss | | | | | | | | | | | | |
| 206 | EW | NE | 5,40 | 4,77 | 25,76 | 18 | -26 | 44 | 1,1 | 0,873 | 989,0 | 1087,9 | |
| | WD | NE | | | 14,15 | 18 | -26 | 44 | 1,1 | 0,852 | 530,2 | 583,2 | |
| | SUM | | | | | | | | | | | 1519,1 | 1671,0 |
| | The total heat loss | | | | | | | | | | | | |
| 210 | EW | NE | 5,40 | 4,77 | 25,76 | 18 | -26 | 44 | 1,1 | 0,873 | 989,0 | 1087,9 | |
| | WD | NE | | | 14,15 | 18 | -26 | 44 | 1,1 | 0,852 | 530,2 | 583,2 | |
| | SUM | | | | | | | | | | | 1519,1 | 1671,0 |
| | The total heat loss | | | | | | | | | | | | |
| 211 | EW | NE | 5,40 | 4,77 | 25,76 | 18 | -26 | 44 | 1,1 | 0,873 | 989,0 | 1087,9 | |
| | WD | NE | | | 14,15 | 18 | -26 | 44 | 1,1 | 0,852 | 530,2 | 583,2 | |
| | SUM | | | | | | | | | | | 1519,1 | 1671,0 |
| | The total heat loss | | | | | | | | | | | | |
| 212 | EW | NE | 5,40 | 4,77 | 25,76 | 18 | -26 | 44 | 1,1 | 0,873 | 989,0 | 1087,9 | |
| | WD | NE | | | 14,15 | 18 | -26 | 44 | 1,1 | 0,852 | 530,2 | 583,2 | |
| | SUM | | | | | | | | | | | 1519,1 | 1671,0 |
| | The total heat loss | | | | | | | | | | | | |
| 213 | EW | CB | 5,40 | 4,77 | 25,76 | 18 | -26 | 44 | 1,1 | 0,873 | 989,0 | 1087,9 | |
| | WD | CB | | | 14,15 | 18 | -26 | 44 | 1,1 | 0,852 | 530,2 | 583,2 | |
| | SUM | | | | | | | | | | | 1519,1 | 1671,0 |
| | The total heat loss | | | | | | | | | | | | |
| 214 | EW1 | NE | 9,65 | 4,77 | 46,03 | 20 | -26 | 46 | 1,15 | 0,873 | 1847,6 | 2124,8 | |
| | EW2 | NW | 9,43 | 4,77 | 44,98 | 20 | -26 | 46 | 1,15 | 0,873 | 1805,5 | 2076,4 | |
| | WD1 | NE | | | 14,15 | 20 | -26 | 46 | 1,15 | 0,852 | 554,3 | 637,4 | |
| | WD2 | NW | | | 6,88 | 20 | -26 | 46 | 1,15 | 0,873 | 276,2 | 317,6 | |
| | CR | | | | 9,51 | 20 | 5 | 15 | 1 | 1,103 | 157,3 | 157,3 | |
| | SUM | | | | | | | | | | | 4640,9 | 5313,5 |
| The total heat loss | | | | | | | | | | | | | 5313 |
| 216-tambour | EW1 | NW | 10,54 | 4,77 | 50,28 | 16 | -26 | 42 | 1,15 | 0,873 | 1842,6 | 2119,0 | |
| | EW2 | NE | 3,89 | 4,77 | 18,56 | 16 | -26 | 42 | 1,15 | 0,873 | 680,0 | 782,0 | |
| | SUM | | | | | | | | | | | 2522,6 | 2901,0 |
| | The total heat loss | | | | | | | | | | | | |

APPENDIX 2(11).

Heat loss calculation

| | | | | | | | | | | | | |
|--|----------------------------|----|-------|------|-------|----|-----|----|------|-------|--------|-------------|
| 218 | EW | NW | 3,35 | 4,77 | 15,98 | 16 | -26 | 42 | 1,1 | 0,873 | 585,6 | 644,2 |
| | SUM | | | | | | | | | | 585,6 | 644,2 |
| | The total heat loss | | | | | | | | | | | 644 |
| 219-staff room | EW1 | NW | 4,48 | 4,77 | 21,37 | 22 | -26 | 48 | 1,15 | 0,873 | 895,1 | 1029,3 |
| | EW2 | SW | 4,13 | 4,77 | 19,70 | 22 | -26 | 48 | 1,1 | 0,873 | 825,1 | 907,6 |
| | IW | | 4,17 | 4,77 | 19,89 | 22 | -26 | 48 | 1 | 2,303 | 2198,8 | 2198,8 |
| | SUM | | | | | | | | | | 3919,0 | 4135,8 |
| | The total heat loss | | | | | | | | | | | 4136 |
| 220-technical room | IW | | 6,30 | 4,77 | 30,05 | 16 | -26 | 42 | 1 | 2,303 | 2906,7 | 2906,7 |
| | SUM | | | | | | | | | | 2906,7 | 2906,7 |
| | The total heat loss | | | | | | | | | | | 2907 |
| 220-technical room | EW | | 6,30 | 2,50 | 15,75 | 16 | -26 | 42 | 1 | 0,873 | 577,2 | 577,2 |
| | WD | | | | 4,21 | 16 | -26 | 42 | 1 | 0,852 | 150,6 | 150,6 |
| | SUM | | | | | | | | | | 727,8 | 727,8 |
| | The total heat loss | | | | | | | | | | | 728 |
| 222-WC | EW | SW | 4,12 | 4,77 | 19,65 | 16 | -26 | 42 | 1 | 0,873 | 720,2 | 720,2 |
| | SUM | | | | | | | | | | 720,2 | 720,2 |
| | The total heat loss | | | | | | | | | | | 720 |
| 223-WC | EW | SW | 3,36 | 4,77 | 16,03 | 16 | -26 | 42 | 1 | 0,873 | 587,4 | 587,4 |
| | SUM | | | | | | | | | | 587,4 | 587,4 |
| | The total heat loss | | | | | | | | | | | 587 |
| 224 | EW1 | SW | 10,88 | 4,77 | 51,90 | 20 | -26 | 46 | 1 | 0,873 | 2083,1 | 2083,1 |
| | EW2 | SE | 6,76 | 4,77 | 32,25 | 20 | -26 | 46 | 1 | 0,873 | 1294,3 | 1294,3 |
| | CR | | | | 77,94 | 20 | -26 | 46 | 1 | 0,230 | 824,6 | 824,6 |
| | SUM | | | | | | | | | | 4202,1 | 4202,1 |
| | The total heat loss | | | | | | | | | | | 4202 |
| The sum of heat loss of second floor =49990 W | | | | | | | | | | | | |
| Third floor | | | | | | | | | | | | |
| 303-hall | EW1 | SW | 5,42 | 4,24 | 22,98 | 18 | -26 | 44 | 1,05 | 0,873 | 882,3 | 926,5 |
| | EW2 | NW | 5,40 | 4,24 | 6,36 | 18 | -26 | 44 | 1,1 | 0,873 | 244,2 | 268,6 |
| | WD1 | SW | | | 6,36 | 18 | -26 | 44 | 1,05 | 0,852 | 238,3 | 250,2 |
| | WD2 | NW | | | 7,75 | 18 | -26 | 44 | 1,1 | 0,852 | 290,4 | 319,4 |
| | SUM | | | | | | | | | | 1655,2 | 1764,7 |
| | The total heat loss | | | | | | | | | | | 1765 |
| 304 | EW | SE | 6,84 | 4,24 | 29,00 | 18 | -26 | 44 | 1 | 0,873 | 1113,5 | 1113,5 |
| | WD | SE | | | 15,27 | 18 | -26 | 44 | 1 | 0,852 | 572,1 | 572,1 |
| | SUM | | | | | | | | | | 1685,6 | 1685,6 |
| | The total heat loss | | | | | | | | | | | 1686 |
| 305 | EW | SE | 6,84 | 4,24 | 29,00 | 18 | -26 | 44 | 1,05 | 0,873 | 1113,5 | 1169,2 |
| | WD | SE | | | 24,84 | 18 | -26 | 44 | 1,05 | 0,852 | 930,7 | 977,2 |
| | SUM | | | | | | | | | | 2044,2 | 2146,4 |
| | The total heat loss | | | | | | | | | | | 2146 |
| 306 | EW | SE | 11,82 | 4,24 | 50,12 | 18 | -26 | 44 | 1,05 | 0,873 | 1924,2 | 2020,4 |

APPENDIX 2(12).

Heat loss calculation

| | | | | | | | | | | | | |
|----------------------------|----------------------------|----|-------|------|-------|----|-----|----|------|-------|-------------|-------------|
| | WD | SE | | | 24,84 | 18 | -26 | 44 | 1,05 | 0,852 | 930,7 | 977,2 |
| | SUM | | | | | | | | | | 2854,9 | 2997,6 |
| | The total heat loss | | | | | | | | | | | 2998 |
| 307 | EW1 | SE | 5,92 | 4,24 | 25,10 | 20 | -26 | 46 | 1,15 | 0,873 | 1007,5 | 1158,7 |
| | EW2 | E | 6,00 | 4,24 | 25,44 | 20 | -26 | 46 | 1,15 | 0,873 | 1021,2 | 1174,3 |
| | EW3 | NE | 5,35 | 4,24 | 22,68 | 20 | -26 | 46 | 1,15 | 0,873 | 910,5 | 1047,1 |
| | WD1 | SE | | | 12,42 | 20 | -26 | 46 | 1,15 | 0,852 | 486,5 | 559,5 |
| | WD2 | E | | | 11,06 | 20 | -26 | 46 | 1,15 | 0,852 | 433,2 | 498,2 |
| | WD3 | NE | | | 11,84 | 20 | -26 | 46 | 1,15 | 0,852 | 463,8 | 533,3 |
| | SUM | | | | | | | | | | 4322,7 | 4971,1 |
| The total heat loss | | | | | | | | | | | 4971 | |
| 308 | EW | NE | 11,50 | 4,24 | 48,76 | 18 | -26 | 44 | 1,1 | 0,873 | 1872,1 | 2059,3 |
| | WD | NE | | | 28,30 | 18 | -26 | 44 | 1,1 | 0,852 | 1060,3 | 1166,4 |
| | SUM | | | | | | | | | | 2932,4 | 3225,7 |
| The total heat loss | | | | | | | | | | | 3226 | |
| 309 | EW | NE | 5,40 | 4,24 | 22,90 | 18 | -26 | 44 | 1,1 | 0,873 | 879,1 | 967,0 |
| | WD | NE | | | 11,84 | 18 | -26 | 44 | 1,1 | 0,852 | 443,6 | 488,0 |
| | SUM | | | | | | | | | | 1322,7 | 1455,0 |
| The total heat loss | | | | | | | | | | | 1455 | |
| 310 | EW | NE | 5,40 | 4,24 | 22,90 | 18 | -26 | 44 | 1,1 | 0,873 | 879,1 | 967,0 |
| | WD | NE | | | 11,84 | 18 | -26 | 44 | 1,1 | 0,852 | 443,6 | 488,0 |
| | SUM | | | | | | | | | | 1322,7 | 1455,0 |
| The total heat loss | | | | | | | | | | | 1455 | |
| 311 | EW | NE | 5,40 | 4,24 | 22,90 | 18 | -26 | 44 | 1,1 | 0,873 | 879,1 | 967,0 |
| | WD | NE | | | 11,84 | 18 | -26 | 44 | 1,1 | 0,852 | 443,6 | 488,0 |
| | SUM | | | | | | | | | | 1322,7 | 1455,0 |
| The total heat loss | | | | | | | | | | | 1455 | |
| 312 | EW | NE | 5,40 | 4,24 | 22,90 | 18 | -26 | 44 | 1,1 | 0,87 | 879,1 | 967,0 |
| | WD | NE | | | 11,84 | 18 | -26 | 44 | 1,1 | 0,852 | 443,6 | 488,0 |
| | SUM | | | | | | | | | | 1322,7 | 1455,0 |
| The total heat loss | | | | | | | | | | | 1455 | |
| 313 | EW | NE | 5,40 | 4,24 | 22,90 | 18 | -26 | 44 | 1,1 | 0,87 | 879,1 | 967,0 |
| | WD | NE | | | 11,84 | 18 | -26 | 44 | 1,1 | 0,852 | 443,6 | 488,0 |
| | SUM | | | | | | | | | | 1322,7 | 1455,0 |
| The total heat loss | | | | | | | | | | | 1455 | |
| 314 | EW1 | NE | 9,65 | 4,24 | 40,92 | 20 | -26 | 46 | 1,15 | 0,873 | 1642,4 | 1888,7 |
| | EW2 | NW | 5,87 | 4,24 | 24,89 | 20 | -26 | 46 | 1,15 | 0,873 | 999,0 | 1148,9 |
| | IW3 | | 1,55 | 4,24 | 6,57 | 20 | 5 | 15 | 1 | 2,610 | 257,3 | 257,3 |
| | IW4 | | 2,98 | 4,24 | 12,64 | 20 | 5 | 15 | 1 | 2,610 | 494,7 | 494,7 |
| | WD1 | NE | | | 11,84 | 20 | -26 | 46 | 1,15 | 0,852 | 463,8 | 533,3 |
| | WD2 | NW | | | 11,84 | 20 | -26 | 46 | 1,15 | 0,852 | 463,8 | 533,3 |
| | SUM | | | | | | | | | | 4320,9 | 4856,2 |
| The total heat loss | | | | | | | | | | | 4856 | |

APPENDIX 2(13).

Heat loss calculation

| | | | | | | | | | | | | |
|--|----------------------------|----|-------|------|-------|----|-----|----|------|-------|--------|-------------|
| 315 | EW1 | NW | 10,54 | 4,24 | 44,69 | 16 | -26 | 42 | 1,15 | 0,873 | 1637,8 | 1883,5 |
| | EW2 | NE | 3,86 | 4,24 | 16,37 | 16 | -26 | 42 | 1,15 | 0,873 | 599,8 | 689,8 |
| | SUM | | | | | | | | | | 2237,7 | 2573,3 |
| | The total heat loss | | | | | | | | | | | 2573 |
| 318 | EW | NW | 3,35 | 4,24 | 14,20 | 16 | -26 | 42 | 1,1 | 0,873 | 520,6 | 572,6 |
| | SUM | | | | | | | | | | 520,6 | 572,6 |
| | The total heat loss | | | | | | | | | | | 573 |
| 319-staff room | EW1 | NW | 4,48 | 4,24 | 19,00 | 22 | -26 | 48 | 1,15 | 0,873 | 795,6 | 915,0 |
| | EW2 | SW | 4,13 | 4,24 | 17,51 | 22 | -26 | 48 | 1,1 | 0,873 | 733,5 | 806,8 |
| | IW3 | | 4,17 | 4,24 | 17,68 | 22 | -26 | 48 | 1 | 2,303 | 1954,5 | 1954,5 |
| | SUM | | | | | | | | | | 3483,6 | 3676,3 |
| | The total heat loss | | | | | | | | | | | 3676 |
| 320-technical room | IW | | 6,30 | 4,24 | 26,71 | 16 | -26 | 42 | 1 | 2,303 | 2583,7 | 2583,7 |
| | SUM | | | | | | | | | | 2583,7 | 2583,7 |
| | The total heat loss | | | | | | | | | | | 2584 |
| 322-WC | EW | SW | 4,12 | 4,24 | 17,47 | 16 | -26 | 42 | 1 | 0,873 | 640,2 | 640,2 |
| | SUM | | | | | | | | | | 640,2 | 640,2 |
| | The total heat loss | | | | | | | | | | | 640 |
| 323-WC | EW | SW | 3,36 | 4,24 | 14,25 | 16 | -26 | 42 | 1 | 0,873 | 522,1 | 522,1 |
| | SUM | | | | | | | | | | 522,1 | 522,1 |
| | The total heat loss | | | | | | | | | | | 522 |
| 324 | EW1 | SW | 10,88 | 4,24 | 46,13 | 20 | -26 | 46 | 1 | 0,873 | 1851,7 | 1851,7 |
| | EW2 | SE | 6,76 | 4,24 | 28,66 | 20 | -26 | 46 | 1 | 0,873 | 1150,5 | 1150,5 |
| | SUM | | | | | | | | | | 3002,2 | 3002,2 |
| | The total heat loss | | | | | | | | | | | 3002 |
| The sum of heat loss of third floor = 42600 W | | | | | | | | | | | | |
| Fourth floor | | | | | | | | | | | | |
| 403 | EW | SE | 6,84 | 4,29 | 29,34 | 22 | -26 | 48 | 1 | 0,873 | 1229,1 | 1229,1 |
| | WD | SE | | | 14,34 | 22 | -26 | 48 | 1 | 0,852 | 586,1 | 586,1 |
| | SUM | | | | | | | | | | 1815,2 | 1815,2 |
| | The total heat loss | | | | | | | | | | | 1815 |
| 406 | EW | SE | 16,70 | 4,29 | 71,64 | 22 | -26 | 48 | 1 | 0,873 | 3000,8 | 3000,8 |
| | WD | SE | | | 34,20 | 22 | -26 | 48 | 1 | 0,852 | 1397,9 | 1397,9 |
| | IW1 | | 2,31 | 4,29 | 9,91 | 22 | 16 | 6 | 1 | 6,525 | 388,0 | 388,0 |
| | IW2 | | 2,50 | 4,29 | 10,73 | 22 | 16 | 6 | 1 | 6,525 | 419,9 | 419,9 |
| | SUM | | | | | | | | | | 5206,5 | 5206,5 |
| | The total heat loss | | | | | | | | | | | 5206 |
| 407 | EW | NE | 22,40 | 4,29 | 96,10 | 22 | -26 | 48 | 1,1 | 0,873 | 4025,0 | 4427,5 |
| | WD | NE | | | 43,52 | 22 | -26 | 48 | 1,1 | 0,852 | 1778,8 | 1956,7 |
| | SUM | | | | | | | | | | 5803,8 | 6384,2 |
| | The total heat loss | | | | | | | | | | | 6384 |
| 408-hall | EW1 | NE | 10,78 | 4,29 | 46,25 | 22 | -26 | 48 | 1,15 | 0,873 | 1937,0 | 2227,6 |
| | EW2 | E | 6,34 | 4,29 | 27,20 | 22 | -26 | 48 | 1,15 | 0,873 | 1139,2 | 1310,1 |

APPENDIX 2(14).

Heat loss calculation

| | | | | | | | | | | | | | |
|----------------------------|----------------------------|----|-------|------|-------|----|-----|----|------|-------|--------|-------------|------------|
| | EW3 | SE | 11,67 | 4,29 | 50,06 | 22 | -26 | 48 | 1,15 | 0,873 | 2096,9 | 2411,5 | |
| | EW4 | SW | 5,42 | 4,29 | 23,25 | 22 | -26 | 48 | 1,15 | 0,873 | 973,9 | 1120,0 | |
| | WD1 | NE | | | 21,76 | 22 | -26 | 48 | 1,15 | 0,852 | 889,4 | 1022,8 | |
| | WD2 | E | | | 9,32 | 22 | -26 | 48 | 1,15 | 0,852 | 380,9 | 438,1 | |
| | WD3 | SE | | | 22,80 | 22 | -26 | 48 | 1,15 | 0,852 | 931,9 | 1071,7 | |
| | WD4 | SW | | | 6,94 | 22 | -26 | 48 | 1,15 | 0,852 | 283,7 | 326,2 | |
| | SUM | | | | | | | | | | | 8633,0 | 9927,9 |
| The total heat loss | | | | | | | | | | | | 9928 | |
| 409 | EW | NE | 16,20 | 4,29 | 69,50 | 22 | -26 | 48 | 1,15 | 0,873 | 2910,9 | 3347,5 | |
| | WD | NE | | | 32,64 | 22 | -26 | 48 | 1,15 | 0,852 | 1334,1 | 1534,2 | |
| | SUM | | | | | | | | | | | 4245,0 | 4881,8 |
| The total heat loss | | | | | | | | | | | | 4882 | |
| 411 | EW1 | NE | 4,24 | 4,29 | 18,19 | 24 | -26 | 50 | 1,15 | 0,873 | 793,6 | 912,7 | |
| | EW2 | NW | 5,60 | 4,29 | 24,02 | 24 | -26 | 50 | 1,15 | 0,873 | 1048,2 | 1205,4 | |
| | IW3 | | 1,50 | 4,29 | 6,44 | 24 | 5 | 19 | 1 | 2,060 | 251,9 | 251,9 | |
| | WD1 | NE | | | 5,30 | 24 | -26 | 50 | 1,15 | 0,852 | 225,7 | 259,5 | |
| | SUM | | | | | | | | | | | 2319,3 | 2629,4 |
| The total heat loss | | | | | | | | | | | | 2629 | |
| 412-staff room | IW | | 2,98 | 4,29 | 12,78 | 16 | 5 | 11 | 1 | 3,559 | 500,5 | 500,5 | |
| | SUM | | | | | | | | | | | 500,5 | 500,5 |
| | The total heat loss | | | | | | | | | | | | 500 |
| 422-staff room | EW | NW | 2,58 | 4,29 | 11,07 | 16 | -26 | 42 | 1,1 | 0,873 | 405,6 | 446,2 | |
| | SUM | | | | | | | | | | | 405,6 | 446,2 |
| | The total heat loss | | | | | | | | | | | | 446 |
| 423-cloak room | EW1 | NW | 5,30 | 4,29 | 22,74 | 18 | -26 | 44 | 1,15 | 0,873 | 873,0 | 1003,9 | |
| | EW2 | SW | 4,55 | 4,29 | 19,52 | 18 | -26 | 44 | 1,15 | 0,873 | 749,4 | 861,9 | |
| | IW | | 1,66 | 4,29 | 7,12 | 18 | 5 | 13 | 1 | 3,012 | 278,8 | 278,8 | |
| | SUM | | | | | | | | | | | 1901,3 | 2144,6 |
| The total heat loss | | | | | | | | | | | | 2145 | |
| 425-staff room | IW | | 1,76 | 4,29 | 7,55 | 16 | 5 | 11 | 1 | 3,559 | 295,6 | 295,6 | |
| | SUM | | | | | | | | | | | 295,6 | 295,6 |
| | The total heat loss | | | | | | | | | | | | 296 |
| 426-technical room | IW | | 2,67 | 4,29 | 11,45 | 16 | 5 | 11 | 1 | 3,559 | 448,4 | 448,4 | |
| | SUM | | | | | | | | | | | 448,4 | 448,4 |
| | The total heat loss | | | | | | | | | | | | 448 |
| 426-technical room | IW | | 3,50 | 4,29 | 15,02 | 16 | 5 | 11 | 1 | 3,559 | 587,8 | 587,8 | |
| | SUM | | | | | | | | | | | 587,8 | 587,8 |
| | The total heat loss | | | | | | | | | | | | 588 |
| 429-hall (2) | IW | | 1,36 | 4,29 | 5,83 | 16 | 5 | 11 | 1 | 3,559 | 228,4 | 228,4 | |
| | EW2 | | 5,40 | 4,29 | 23,17 | 16 | 5 | 11 | 1 | 0,873 | 222,4 | 222,4 | |
| | WD | | | | 7,75 | 16 | 5 | 11 | 1 | 0,852 | 72,6 | 72,6 | |
| | SUM | | | | | | | | | | | 523,4 | 523,4 |
| | The total heat loss | | | | | | | | | | | | 523 |

APPENDIX 2(15).

Heat loss calculation

| | | | | | | | | | | | | |
|---|----------------------------|----|-------|------|-------|----|-----|----|------|-------|--------|-------------|
| 431-tambour | EW1 | NW | 10,54 | 4,29 | 45,22 | 16 | -26 | 42 | 1,15 | 0,873 | 1657,2 | 1905,7 |
| | EW2 | NE | 3,86 | 4,29 | 16,56 | 16 | -26 | 42 | 1,15 | 0,873 | 606,9 | 697,9 |
| | SUM | | | | | | | | | | 2264,0 | 2603,6 |
| | The total heat loss | | | | | | | | | | | 2604 |
| 435-WC | EW | SW | 4,12 | 4,29 | 17,67 | 16 | -26 | 42 | 1 | 0,873 | 647,8 | 647,8 |
| | | | | | | | | | | | | |
| | SUM | | | | | | | | | | 647,8 | 647,8 |
| | The total heat loss | | | | | | | | | | | 648 |
| 436-WC | EW | SW | 3,36 | 4,29 | 14,41 | 16 | -26 | 42 | 1 | 0,873 | 528,3 | 528,3 |
| | | | | | | | | | | | | |
| | SUM | | | | | | | | | | 528,3 | 528,3 |
| | The total heat loss | | | | | | | | | | | 528 |
| 437-Utility room | EW | | 1,00 | 4,29 | 4,29 | 16 | -26 | 42 | 1 | 0,873 | 157,2 | 157,2 |
| | | | | | | | | | | | | |
| | SUM | | | | | | | | | | 157,2 | 157,2 |
| | The total heat loss | | | | | | | | | | | 157 |
| 438-administration | W | SE | 7,50 | 4,29 | 32,18 | 20 | -26 | 46 | 1,1 | 0,873 | 1291,5 | 1420,6 |
| | WD | | | | 6,38 | 20 | -26 | 46 | 1,1 | 0,852 | 249,9 | 274,9 |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | SUM | | | | | | | | | | 1541,4 | 1695,5 |
| | The total heat loss | | | | | | | | | | | 1696 |
| The sum of heat loss of fourth floor = 35850 W | | | | | | | | | | | | |
| Fifth floor | | | | | | | | | | | | |
| 503-hall | EW1 | NE | 5,40 | 4,19 | 22,63 | 18 | -26 | 44 | 1,1 | 0,873 | 868,7 | 955,6 |
| | EW2 | SW | | 4,19 | 4,19 | 18 | -26 | 44 | 1 | 0,873 | 160,9 | 160,9 |
| | WD1 | NE | | | 5,15 | 18 | -26 | 44 | 1,1 | 0,852 | 193,0 | 212,3 |
| | WD2 | SW | | | 6,25 | 18 | -26 | 44 | 1 | 0,852 | 234,2 | 234,2 |
| | SUM | | | | | | | | | | 1456,7 | 1562,9 |
| | The total heat loss | | | | | | | | | | | 1563 |
| 504 | EW | SE | 6,68 | 4,19 | 27,99 | 18 | -26 | 44 | 1,05 | 0,873 | 1074,6 | 1128,4 |
| | WD | SE | | | 6,15 | 18 | -26 | 44 | 1,05 | 0,852 | 230,4 | 241,9 |
| | SUM | | | | | | | | | | 1305,1 | 1370,3 |
| | The total heat loss | | | | | | | | | | | 1370 |
| 505 | EW | SE | 11,33 | 4,19 | 47,47 | 18 | -26 | 44 | 1,05 | 0,873 | 1822,7 | 1913,8 |
| | WD | SE | | | 10,20 | 18 | -26 | 44 | 1,05 | 0,852 | 382,2 | 401,3 |
| | SUM | | | | | | | | | | 2204,9 | 2315,1 |
| | The total heat loss | | | | | | | | | | | 2315 |
| 506 | EW | SE | 12,00 | 4,19 | 50,28 | 18 | -26 | 44 | 1,05 | 0,873 | 1930,5 | 2027,0 |
| | WD | SE | | | 10,20 | 18 | -26 | 44 | 1,05 | 0,852 | 382,2 | 401,3 |
| | SUM | | | | | | | | | | 2312,6 | 2428,3 |
| | The total heat loss | | | | | | | | | | | 2428 |
| 507 | EW1 | SE | 5,46 | 4,19 | 22,88 | 20 | -26 | 46 | 1,15 | 0,873 | 918,3 | 1056,0 |

APPENDIX 2(16).

Heat loss calculation

| | | | | | | | | | | | | | |
|--------------------|----------------------------|----|-------|------|-------|----|-----|----|------|-------|--------|--------|-------------|
| | EW2 | E | 5,71 | 4,19 | 23,92 | 20 | -26 | 46 | 1,15 | 0,873 | 960,3 | 1104,4 | |
| | EW3 | NE | 5,70 | 4,19 | 23,88 | 20 | -26 | 46 | 1,15 | 0,873 | 958,7 | 1102,5 | |
| | WD1 | SE | | | 5,10 | 20 | -26 | 46 | 1,15 | 0,852 | 199,8 | 229,7 | |
| | D | E | | | 9,17 | 20 | -26 | 46 | 1,15 | 1,103 | 465,3 | 535,1 | |
| | WD3 | NE | | | 5,10 | 20 | -26 | 46 | 1,15 | 0,852 | 199,8 | 229,7 | |
| | SUM | | | | | | | | | | | 3702,1 | 4257,4 |
| | The total heat loss | | | | | | | | | | | | 4257 |
| 508 | EW | NE | 11,50 | 4,19 | 48,19 | 18 | -26 | 44 | 1,1 | 0,873 | 1850,0 | 2035,0 | |
| | WD | NE | | | 10,20 | 18 | -26 | 44 | 1,1 | 0,852 | 382,2 | 420,4 | |
| | SUM | | | | | | | | | | | 2232,2 | 2455,4 |
| | The total heat loss | | | | | | | | | | | | 2455 |
| 509 | EW | NE | 5,40 | 4,19 | 22,63 | 18 | -26 | 44 | 1,1 | 0,873 | 868,7 | 955,6 | |
| | WD | NE | | | 5,10 | 18 | -26 | 44 | 1,1 | 0,852 | 191,1 | 210,2 | |
| | SUM | | | | | | | | | | | 1059,8 | 1165,8 |
| | The total heat loss | | | | | | | | | | | | 1166 |
| 510 | EW | NE | 5,40 | 4,19 | 22,63 | 18 | -26 | 44 | 1,1 | 0,873 | 868,7 | 955,6 | |
| | WD | NE | | | 5,10 | 18 | -26 | 44 | 1,1 | 0,852 | 191,1 | 210,2 | |
| | SUM | | | | | | | | | | | 1059,8 | 1165,8 |
| | The total heat loss | | | | | | | | | | | | 1166 |
| 511 | EW | NE | 5,40 | 4,19 | 22,63 | 18 | -26 | 44 | 1,1 | 0,873 | 868,7 | 955,6 | |
| | WD | NE | | | 5,10 | 18 | -26 | 44 | 1,1 | 0,852 | 191,1 | 210,2 | |
| | SUM | | | | | | | | | | | 1059,8 | 1165,8 |
| | The total heat loss | | | | | | | | | | | | 1166 |
| 512 | EW | NE | 5,40 | 4,19 | 22,63 | 18 | -26 | 44 | 1,1 | 0,873 | 868,7 | 955,6 | |
| | WD | NE | | | 5,10 | 18 | -26 | 44 | 1,1 | 0,852 | 191,1 | 210,2 | |
| | SUM | | | | | | | | | | | 1059,8 | 1165,8 |
| | The total heat loss | | | | | | | | | | | | 1166 |
| 513 | EW | NE | 5,40 | 4,19 | 22,63 | 18 | -26 | 44 | 1,1 | 0,873 | 868,7 | 955,6 | |
| | WD | NE | | | 5,10 | 18 | -26 | 44 | 1,1 | 0,852 | 191,1 | 210,2 | |
| | SUM | | | | | | | | | | | 1059,8 | 1165,8 |
| | The total heat loss | | | | | | | | | | | | 1166 |
| 514 | EW1 | NE | 9,64 | 4,19 | 40,39 | 20 | -26 | 46 | 1,15 | 0,873 | 1621,3 | 1864,5 | |
| | EW2 | NW | 5,96 | 4,19 | 24,97 | 20 | -26 | 46 | 1,15 | 0,873 | 1002,4 | 1152,7 | |
| | IW3 | | 1,55 | 4,19 | 6,49 | 20 | 5 | 15 | 1 | 2,610 | 254,3 | 254,3 | |
| | IW4 | | 2,98 | 4,19 | 12,49 | 20 | 5 | 15 | 1 | 2,610 | 488,8 | 488,8 | |
| | WD | NE | | | 7,65 | 20 | -26 | 46 | 1,15 | 0,852 | 299,7 | 344,6 | |
| | SUM | | | | | | | | | | | 3666,4 | 4104,9 |
| | The total heat loss | | | | | | | | | | | | 4105 |
| 516-tambour | EW1 | NW | 10,54 | 4,19 | 44,16 | 16 | -26 | 42 | 1,15 | 0,873 | 1618,5 | 1861,3 | |
| | EW2 | NE | 3,86 | 4,19 | 16,17 | 16 | -26 | 42 | 1,15 | 0,873 | 592,7 | 681,7 | |
| | SUM | | | | | | | | | | | 2211,3 | 2543,0 |
| | The total heat loss | | | | | | | | | | | | 2543 |
| ility | EW | NW | 3,31 | 4,19 | 13,87 | 16 | -26 | 42 | 1,1 | 0,873 | 508,3 | 559,1 | |

APPENDIX 2(17).

Heat loss calculation

| | | | | | | | | | | | | | | |
|--|-----|----|-------|------|-------|----|-----|----|------|-------|----------------------------|----------------------------|-------------|-------------|
| | | | | | | | | | | | SUM | 508,3 | 559,1 | |
| | | | | | | | | | | | The total heat loss | | 559 | |
| 519-staff room | EW1 | NW | 5,30 | 4,19 | 22,21 | 22 | -26 | 48 | 1,15 | 0,873 | 930,1 | 1069,7 | | |
| | EW2 | SW | 4,55 | 4,19 | 19,06 | 22 | -26 | 48 | 1,15 | 0,873 | 798,5 | 918,3 | | |
| | IW3 | | 1,66 | 4,19 | 6,96 | 22 | 5 | 17 | 1 | 2,303 | 272,3 | 272,3 | | |
| | IW4 | | 1,95 | 4,19 | 8,17 | 22 | 5 | 17 | 1 | 2,30 | 319,9 | 319,9 | | |
| | | | | | | | | | | | | SUM | 2320,8 | 2580,1 |
| | | | | | | | | | | | The total heat loss | | 2580 | |
| 520-technical room | EW | | 6,70 | 4,19 | 28,07 | 16 | 5 | 11 | 1 | 3,559 | 1099,0 | 1099,0 | | |
| | | | | | | | | | | | | SUM | 1099,0 | 1099,0 |
| | | | | | | | | | | | | The total heat loss | | 1099 |
| 522-WC | EW | SW | 4,12 | 4,19 | 17,26 | 16 | -26 | 42 | 1 | 0,873 | 632,7 | 632,7 | | |
| | KP | | | | 33,60 | 16 | -26 | 42 | 1 | 0,209 | 294,9 | 294,9 | | |
| | | | | | | | | | | | | SUM | 927,6 | 927,6 |
| | | | | | | | | | | | | The total heat loss | | 928 |
| 523-WC | EW | SW | 3,36 | 4,19 | 14,08 | 16 | -26 | 42 | 1 | 0,873 | 516,0 | 516,0 | | |
| | KP | | | | 34,03 | 16 | -26 | 42 | 2 | 0,209 | 298,7 | 597,4 | | |
| | | | | | | | | | | | | SUM | 814,7 | 1113,4 |
| | | | | | | | | | | | | The total heat loss | | 1113 |
| 524 | EW1 | SE | 7,50 | 4,19 | 31,43 | 20 | -26 | 46 | 1,1 | 0,873 | 1261,4 | 1387,5 | | |
| | EW2 | SW | 1 | 4,19 | 4,19 | 20 | -26 | 46 | 1,1 | 0,873 | 168,2 | 185,0 | | |
| | WD | | | | 6,38 | 20 | -26 | 46 | 1,1 | 0,852 | 249,9 | 274,9 | | |
| | KP | | | | 59,52 | 20 | -26 | 46 | 2,1 | 0,209 | 572,2 | 1201,7 | | |
| | | | | | | | | | | | | SUM | 2251,7 | 3049,1 |
| | | | | | | | | | | | | The total heat loss | | 3049 |
| The sum of heat loss of fifth floor = 36280 W | | | | | | | | | | | | | | |
| Sixth floor | | | | | | | | | | | | | | |
| 603-hall | EW1 | NW | 5,40 | 3,86 | 20,84 | 18 | -26 | 44 | 1,1 | 0,873 | 800,3 | 880,3 | | |
| | EW2 | SW | 23,16 | 3,86 | 89,40 | 18 | -26 | 44 | 1 | 0,873 | 3432,4 | 3432,4 | | |
| | WD1 | NW | | | 2,62 | 18 | -26 | 44 | 1,1 | 0,852 | 98,2 | 108,0 | | |
| | WD2 | SW | | | 26,40 | 18 | -26 | 44 | 1 | 0,852 | 989,1 | 989,1 | | |
| | WD3 | SW | | | 5,84 | 18 | -26 | 44 | 1 | 0,873 | 224,2 | 224,2 | | |
| | | | | | | | | | | | | SUM | 5544,2 | 5634,0 |
| | | | | | | | | | | | | The total heat loss | | 5634 |
| 604 | EW | SE | 6,68 | 3,86 | 25,78 | 18 | -26 | 44 | 1,05 | 0,873 | 990,0 | 1039,5 | | |
| | WD | SE | | | 2,85 | 18 | -26 | 44 | 1,05 | 0,852 | 106,8 | 112,1 | | |
| | KP | | | | 24,30 | 18 | -26 | 44 | 1 | 0,209 | 223,5 | 223,5 | | |
| | | | | | | | | | | | | SUM | 1320,2 | 1375,1 |
| | | | | | | | | | | | The total heat loss | | 1375 | |
| 605 | EW | SE | 11,30 | 3,86 | 43,62 | 18 | -26 | 44 | 1,05 | 0,873 | 1674,7 | 1758,4 | | |
| | WD | SE | | | 2,85 | 18 | -26 | 44 | 1,05 | 0,852 | 106,8 | 112,1 | | |
| | KP | | | | 33,97 | 18 | -26 | 44 | 1 | 0,209 | 312,4 | 312,4 | | |
| | | | | | | | | | | | | SUM | 2093,9 | 2182,9 |

APPENDIX 2(18).

Heat loss calculation

| | | | | | | | | | | | | |
|------------|----------------------------|----|-------|------|-------|----|-----|----|------|-------|--------|-------------|
| | The total heat loss | | | | | | | | | | | 2183 |
| 606 | EW | SE | 11,93 | 3,86 | 46,05 | 18 | -26 | 44 | 1,05 | 0,873 | 1768,1 | 1856,5 |
| | WD | SE | | | 2,85 | 18 | -26 | 44 | 1,05 | 0,852 | 106,8 | 112,1 |
| | KP | | | | 40,96 | 18 | -26 | 44 | 1 | 0,209 | 376,7 | 376,7 |
| | SUM | | | | | | | | | | 2251,5 | 2345,2 |
| | The total heat loss | | | | | | | | | | | 2345 |
| 607 | EW1 | SE | 5,46 | 3,86 | 21,08 | 20 | -26 | 46 | 1,15 | 0,873 | 846,0 | 972,9 |
| | EW2 | E | 5,71 | 3,86 | 22,04 | 20 | -26 | 46 | 1,15 | 0,873 | 884,7 | 1017,4 |
| | EW3 | NE | 5,70 | 3,86 | 22,00 | 20 | -26 | 46 | 1,15 | 0,873 | 883,2 | 1015,6 |
| | WD1 | SE | | | 2,85 | 20 | -26 | 46 | 1,15 | 0,852 | 111,6 | 128,4 |
| | WD2 | E | | | 2,32 | 20 | -26 | 46 | 1,15 | 0,852 | 90,9 | 104,5 |
| | WD3 | NE | | | 2,85 | 20 | -26 | 46 | 1,15 | 0,852 | 111,6 | 128,4 |
| | KP | | | | 15,81 | 18 | -26 | 44 | 1 | 0,209 | 145,4 | 145,4 |
| | KP | | | | 15,81 | 18 | -26 | 44 | 1 | 0,209 | 145,4 | 145,4 |
| | SUM | | | | | | | | | | 3218,7 | 3657,9 |
| | The total heat loss | | | | | | | | | | | 3658 |
| 608 | EW | NE | 11,02 | 3,86 | 42,54 | 18 | -26 | 44 | 1,05 | 0,873 | 1633,2 | 1714,9 |
| | WD | NE | | | 5,70 | 18 | -26 | 44 | 1,05 | 0,852 | 213,6 | 224,2 |
| | KP | | | | 27,63 | 18 | -26 | 44 | 1 | 0,216 | 262,6 | 262,6 |
| | SUM | | | | | | | | | | 2109,4 | 2201,7 |
| | The total heat loss | | | | | | | | | | | 2202 |
| 609 | EW | NE | 5,40 | 3,86 | 20,84 | 18 | -26 | 44 | 1,1 | 0,873 | 800,3 | 880,3 |
| | KP | | | | 13,50 | 18 | -26 | 44 | 1 | 0,209 | 124,1 | 124,1 |
| | SUM | | | | | | | | | | 924,4 | 1004,5 |
| | The total heat loss | | | | | | | | | | | 1004 |
| 610 | EW | NE | 5,40 | 3,86 | 20,84 | 18 | -26 | 44 | 1,1 | 0,873 | 800,3 | 880,3 |
| | KP | | | | 13,50 | 18 | -26 | 44 | 1 | 0,209 | 124,1 | 124,1 |
| | SUM | | | | | | | | | | 924,4 | 1004,5 |
| | The total heat loss | | | | | | | | | | | 1004 |
| 611 | EW | NE | 5,40 | 3,86 | 20,84 | 18 | -26 | 44 | 1,1 | 0,873 | 800,3 | 880,3 |
| | KP | | | | 13,50 | 18 | -26 | 44 | 1 | 0,209 | 124,1 | 124,1 |
| | SUM | | | | | | | | | | 924,4 | 1004,5 |
| | The total heat loss | | | | | | | | | | | 1004 |
| 612 | EW | NE | 5,40 | 3,86 | 20,84 | 18 | -26 | 44 | 1,1 | 0,873 | 800,3 | 880,3 |
| | WD | NE | | | 2,55 | 18 | -26 | 44 | 1,1 | 0,852 | 95,5 | 105,1 |
| | KP | | | | 13,50 | 18 | -26 | 44 | 1 | 0,209 | 124,1 | 124,1 |
| | SUM | | | | | | | | | | 1020,0 | 1109,6 |
| | The total heat loss | | | | | | | | | | | 1110 |
| 613 | EW | NE | 5,40 | 3,86 | 20,84 | 18 | -26 | 44 | 1,1 | 0,873 | 800,3 | 880,3 |
| | WD | NE | | | 2,55 | 18 | -26 | 44 | 1,1 | 0,852 | 95,5 | 105,1 |
| | KP | | | | 13,50 | 18 | -26 | 44 | 1 | 0,209 | 124,1 | 124,1 |
| | SUM | | | | | | | | | | 1020,0 | 1109,6 |
| | The total heat loss | | | | | | | | | | | 1110 |

APPENDIX 2(19).

Heat loss calculation

| | | | | | | | | | | | | | |
|--|----------------------------|----|-------|------|-------|----|-----|----|------|-------|--------|--------|-------------|
| 614 | EW1 | NE | 9,64 | 3,86 | 37,21 | 20 | -26 | 46 | 1,15 | 0,873 | 1493,6 | 1717,7 | |
| | EW2 | NW | 5,96 | 3,86 | 23,01 | 20 | -26 | 46 | 1,15 | 0,873 | 923,4 | 1062,0 | |
| | IW3 | | 1,55 | 3,86 | 5,98 | 20 | 5 | 15 | 1 | 2,610 | 234,2 | 234,2 | |
| | IW4 | | 2,98 | 3,86 | 11,50 | 20 | 5 | 15 | 1 | 2,610 | 450,3 | 450,3 | |
| | WD1 | NE | | | 7,65 | 20 | -26 | 46 | 1,15 | 0,852 | 299,7 | 344,6 | |
| | WD2 | NE | | | 7,65 | 20 | -26 | 46 | 1,15 | 0,852 | 299,7 | 344,6 | |
| | KP | | | | 22,50 | 18 | -26 | 44 | 1 | 0,209 | 206,9 | 206,9 | |
| | SUM | | | | | | | | | | | 3907,8 | 4360,3 |
| | The total heat loss | | | | | | | | | | | | 4360 |
| 616-tambour | EW1 | NW | 10,54 | 3,86 | 40,68 | 16 | -26 | 42 | 1,15 | 0,873 | 1491,1 | 1714,7 | |
| | EW2 | NE | 3,86 | 3,86 | 14,90 | 16 | -26 | 42 | 1,15 | 0,873 | 546,1 | 628,0 | |
| | SUM | | | | | | | | | | | 2037,1 | 2342,7 |
| | The total heat loss | | | | | | | | | | | | 2343 |
| 618-utility room | EW | NW | 3,31 | 3,86 | 12,78 | 16 | -26 | 42 | 1,1 | 0,873 | 468,3 | 515,1 | |
| | SUM | | | | | | | | | | | 468,3 | 515,1 |
| | The total heat loss | | | | | | | | | | | | 515 |
| 619-staff room | EW1 | NW | 5,30 | 3,86 | 20,46 | 22 | -26 | 48 | 1,15 | 0,873 | 856,9 | 985,4 | |
| | EW2 | SW | 4,55 | 3,86 | 17,56 | 22 | -26 | 48 | 1,15 | 0,873 | 735,6 | 846,0 | |
| | IW3 | | 1,66 | 3,86 | 6,41 | 22 | 5 | 17 | 1 | 2,303 | 250,9 | 250,9 | |
| | IW4 | | 1,95 | 3,86 | 7,53 | 22 | 5 | 17 | 1 | 2,30 | 294,7 | 294,7 | |
| | SUM | | | | | | | | | | | 2138,1 | 2376,9 |
| | The total heat loss | | | | | | | | | | | | 2377 |
| 620-technical room | IW1 | | 3,17 | 3,86 | 12,24 | 16 | 5 | 11 | 1 | 3,559 | 479,0 | 479,0 | |
| | IW1 | | 0,82 | 3,86 | 3,17 | 16 | 5 | 11 | 1 | 3,559 | 123,9 | 123,9 | |
| | SUM | | | | | | | | | | | 602,9 | 602,9 |
| | The total heat loss | | | | | | | | | | | | 603 |
| 621 | IW1 | | 3,60 | 3,86 | 13,90 | 16 | 5 | 11 | 1 | 3,559 | 544,0 | 544,0 | |
| | SUM | | | | | | | | | | | 544,0 | 544,0 |
| | The total heat loss | | | | | | | | | | | | 544 |
| The sum of heat loss of sixth floor = 33460 W | | | | | | | | | | | | | |
| Mansard | | | | | | | | | | | | | |
| 702-hall | KP | | | | 5,88 | 16 | -26 | 42 | 1 | 0,216 | 53,3 | 53,3 | |
| | SUM | | | | | | | | | | | 53,3 | 53,3 |
| | The total heat loss | | | | | | | | | | | | 53 |
| 703-Technical room | KP | | | | 16,30 | 16 | -26 | 42 | 1 | 0,230 | 157,5 | 157,5 | |
| | SUM | | | | | | | | | | | 157,5 | 157,5 |
| | The total heat loss | | | | | | | | | | | | 157 |
| 704-cloakroom | EW | | 3,60 | 1,50 | 5,40 | 18 | 12 | 6 | 1 | 6,525 | 211,4 | 211,4 | |
| | KP1 | | | | 20,50 | 18 | -26 | 44 | 1 | 0,216 | 194,8 | 194,8 | |
| | SUM | | | | | | | | | | | 406,2 | 406,2 |
| | The total heat loss | | | | | | | | | | | | 406 |
| restoran | EW1 | SW | 23,25 | 3,33 | 77,31 | 22 | -26 | 48 | 1,15 | 0,873 | 3238,0 | 3723,7 | |
| | WD1 | SW | | | 2,55 | 22 | -26 | 48 | 1,15 | 0,852 | 104,2 | 119,9 | |

APPENDIX 2(20).

Heat loss calculation

| | | | | | | | | | | | | | |
|----------------------------|----------------------------|----|--------|------|--------|----|-----|----|------|-------|--------|--------------|--------------|
| | IW2 | | 16,63 | 1,50 | 24,95 | 22 | 12 | 10 | 1 | 6,525 | 1627,7 | 1627,7 | |
| | WD2 | SE | | | 26,67 | 22 | -26 | 48 | 1,05 | 1,724 | 2207,2 | 2317,5 | |
| | IW3 | SE | 1,44 | 1,50 | 2,16 | 22 | 12 | 10 | 1,05 | 6,525 | 140,9 | 148,0 | |
| | IW4 | | 28,18 | 1,50 | 42,27 | 22 | 12 | 10 | 1 | 6,525 | 2758,1 | 2758,1 | |
| | WD2 | NE | | | 57,33 | 22 | -26 | 48 | 1,15 | 1,724 | 4744,6 | 5456,2 | |
| | KP | | | | 400,00 | 22 | -26 | 48 | 1 | 0,209 | 4012,8 | 4012,8 | |
| | D1 | | 1,80 | 0,70 | 1,26 | 22 | 16 | 6 | 1 | 0,000 | 0,0 | 0,0 | |
| | D2 | | 1,80 | 0,70 | 1,26 | 22 | 16 | 6 | 1 | 0,000 | 0,0 | 0,0 | |
| | SUM | | | | | | | | | | | ##### | 20163,8 |
| | The total heat loss | | | | | | | | | | | | 20164 |
| 706-hall | EW1 | | 1,20 | 1,10 | 1,32 | 18 | 12 | 6 | 1 | 6,525 | 51,7 | 51,7 | |
| | EW2 | | 3,25 | 1,10 | 3,58 | 18 | 12 | 6 | 1 | 6,525 | 140,0 | 140,0 | |
| | EW3 | | 3,22 | 1,10 | 3,54 | 18 | 12 | 6 | 1 | 6,525 | 138,7 | 138,7 | |
| | EW4 | | 3,22 | 1,10 | 3,54 | 18 | 12 | 6 | 1 | 6,525 | 138,7 | 138,7 | |
| | WD1 | SW | | | 8,30 | 18 | -26 | 44 | 1 | 1,724 | 629,7 | 629,7 | |
| | WD2 | N | | | 8,30 | 18 | -26 | 44 | 1,1 | 1,724 | 629,7 | 692,6 | |
| | KP | | | | 5,00 | 18 | -26 | 44 | 1 | 0,216 | 47,5 | 47,5 | |
| | SUM | | | | | | | | | | | 1775,8 | 1838,8 |
| The total heat loss | | | | | | | | | | | | 1839 | |
| 707-Tower 1 floor | EW1 | SW | 5,44 | 3,93 | 21,38 | 18 | -26 | 44 | 1,15 | 0,267 | 251,2 | 288,8 | |
| | EW2 | S | 1,21 | 3,93 | 4,76 | 18 | -26 | 44 | 1,15 | 0,267 | 55,9 | 64,2 | |
| | EW3 | SE | 5,27 | 3,93 | 20,71 | 18 | -26 | 44 | 1,15 | 0,267 | 243,3 | 279,8 | |
| | EW4 | E | 0,97 | 3,93 | 3,81 | 18 | -26 | 44 | 1,15 | 0,267 | 44,8 | 51,5 | |
| | EW5 | NE | 5,70 | 3,93 | 22,40 | 18 | -26 | 44 | 1,15 | 0,267 | 263,2 | 302,6 | |
| | SUM | | | | | | | | | | | 858,3 | 987,0 |
| The total heat loss | | | | | | | | | | | | 987 | |
| 738-tower doom | DO | | 132,00 | 1,00 | 132,00 | 22 | -26 | 48 | 1,25 | 1,724 | ##### | 13655,2 | |
| | SUM | | | | | | | | | | | ##### | 13655,2 |
| The total heat loss | | | | | | | | | | | | 13655 | |
| 708-WC | KP1 | | | | 2,80 | 16 | -26 | 42 | 1 | 0,216 | 25,4 | 25,4 | |
| | KP2 | | | | 3,00 | 16 | -26 | 42 | 1 | 0,216 | 27,2 | 27,2 | |
| | SUM | | | | | | | | | | | 52,6 | 52,6 |
| | The total heat loss | | | | | | | | | | | | 53 |
| 709-smoking-room | EW1 | NW | 7,23 | 3,26 | 23,57 | 16 | -26 | 42 | 1 | 0,873 | 863,8 | 863,8 | |
| | EW2 | NE | 3,77 | 3,26 | 12,29 | 16 | -26 | 42 | 1 | 0,873 | 450,4 | 450,4 | |
| | WD1 | NE | | | 2,61 | 16 | -26 | 42 | 1 | 0,852 | 93,3 | 93,3 | |
| | WD2 | NE | | | 2,61 | 16 | -26 | 42 | 1 | 0,852 | 93,3 | 93,3 | |
| | KP | | | | 37,47 | 16 | -26 | 42 | 1 | 0,209 | 328,9 | 328,9 | |
| | SUM | | | | | | | | | | | 1829,8 | 1829,8 |
| The total heat loss | | | | | | | | | | | | 1830 | |
| 710-WC | EW1 | SW | 3,84 | 2,89 | 11,10 | 16 | -26 | 42 | 1 | 0,873 | 406,7 | 406,7 | |
| | KP | | | | 17,93 | 16 | -26 | 42 | 1 | 0,209 | 157,4 | 157,4 | |
| | SUM | | | | | | | | | | | 564,1 | 564,1 |

APPENDIX 2(21).

Heat loss calculation

| | | | | | | | | | | | | | |
|-----------------------------|----------------------------|----|-------|------|-------|----|-----|----|------|-------|--------|--------|------------|
| The total heat loss | | | | | | | | | | | | | 564 |
| 711-WC | KP | | | | 12,20 | 16 | -26 | 42 | 1 | 0,209 | 107,1 | 107,1 | |
| | SUM | | | | | | | | | | | 107,1 | 107,1 |
| | The total heat loss | | | | | | | | | | | | |
| 712-Utility room | KP | | | | 4,12 | 16 | -26 | 42 | 1 | 0,209 | 36,2 | 36,2 | |
| | SUM | | | | | | | | | | | 36,2 | 36,2 |
| | The total heat loss | | | | | | | | | | | | |
| 713-WC | KP | | | | 2,00 | 16 | -26 | 42 | 1 | 0,209 | 17,6 | 17,6 | |
| | SUM | | | | | | | | | | | 17,6 | 17,6 |
| | The total heat loss | | | | | | | | | | | | |
| 714-Utility room | KP | | | | 2,00 | 16 | -26 | 42 | 1 | 0,209 | 17,6 | 17,6 | |
| | SUM | | | | | | | | | | | 17,6 | 17,6 |
| | The total heat loss | | | | | | | | | | | | |
| 715-hall | EW1 | NW | 5,40 | 4,11 | 22,19 | 16 | -26 | 42 | 1,1 | 0,873 | 813,4 | 894,7 | |
| | WD1 | NW | | | 2,61 | 16 | -26 | 42 | 1,1 | 0,852 | 93,3 | 102,7 | |
| | KP1 | | | | 61,59 | 16 | -26 | 42 | 1 | 0,209 | 540,6 | 540,6 | |
| | SUM | | | | | | | | | | | 1447,4 | 1538,0 |
| | The total heat loss | | | | | | | | | | | | |
| 716-Technical room | EW1 | NW | 2,00 | 3,26 | 6,52 | 5 | -26 | 31 | 1 | 0,873 | 176,4 | 176,4 | |
| | KP | | | | 14,21 | 5 | -26 | 31 | 1 | 0,209 | 92,1 | 92,1 | |
| | SUM | | | | | | | | | | | 268,4 | 268,4 |
| | The total heat loss | | | | | | | | | | | | |
| 717-Cloakroom and WC | EW1 | SW | 4,30 | 3,26 | 14,02 | 22 | -26 | 48 | 1,1 | 0,873 | 587,1 | 645,9 | |
| | EW2 | NW | 7,98 | 3,26 | 26,01 | 22 | -26 | 48 | 1,15 | 0,873 | 1089,6 | 1253,1 | |
| | KP | | | | 30,42 | 22 | -26 | 48 | 1 | 0,209 | 305,2 | 305,2 | |
| | SUM | | | | | | | | | | | 1981,9 | 2204,1 |
| | The total heat loss | | | | | | | | | | | | |
| 718-Utility room | KP | | | | 2,87 | 16 | -26 | 42 | 1 | 0,209 | 25,2 | 25,2 | |
| | SUM | | | | | | | | | | | 25,2 | 25,2 |
| | The total heat loss | | | | | | | | | | | | |
| 719-Hall | EW1 | NW | 10,71 | 3,26 | 34,91 | 16 | -26 | 42 | 1,15 | 0,873 | 1279,6 | 1471,5 | |
| | EW2 | NE | 3,91 | 3,26 | 12,75 | 16 | -26 | 42 | 1,15 | 0,873 | 467,2 | 537,2 | |
| | KP | | | | 42,2 | 16 | -26 | 42 | 1 | 0,209 | 370,4 | 370,4 | |
| | SUM | | | | | | | | | | | 2117,2 | 2379,2 |
| | The total heat loss | | | | | | | | | | | | |
| 720-storage room | KP | | | | 7,12 | 16 | -26 | 42 | 1 | 0,209 | 62,5 | 62,5 | |
| | SUM | | | | | | | | | | | 62,5 | 62,5 |
| | The total heat loss | | | | | | | | | | | | |
| 721-storage room | KP | | | | 6,77 | 16 | -26 | 42 | 1 | 0,209 | 59,4 | 59,4 | |
| | SUM | | | | | | | | | | | 59,4 | 59,4 |
| | The total heat loss | | | | | | | | | | | | |
| 722 | KP | | | | 10,00 | 16 | -26 | 42 | 1 | 0,209 | 87,8 | 87,8 | |
| | SUM | | | | | | | | | | | 87,8 | 87,8 |

APPENDIX 2(22).

Heat loss calculation

| | | | | | | | | | | | | |
|--------------------|----------------------------|----|------|------|--------|----|-----|----|------|-------|--------|-------------|
| 723-staff room | The total heat loss | | | | | | | | | | | 88 |
| | KP | | | | 9,50 | 16 | -26 | 42 | 1 | 0,209 | 83,4 | 83,4 |
| | SUM | | | | | | | | | | 83,4 | 83,4 |
| 724-staff room | The total heat loss | | | | | | | | | | | 83 |
| | KP | | | | 7,00 | 16 | -26 | 42 | 1 | 0,209 | 61,4 | 61,4 |
| | SUM | | | | | | | | | | 61,4 | 61,4 |
| 725-Hot shop | The total heat loss | | | | | | | | | | | 61 |
| | KP | | | | 18,48 | 16 | -26 | 42 | 1 | 0,209 | 162,2 | 162,2 |
| | SUM | | | | | | | | | | 162,2 | 162,2 |
| 726-Cold shop | The total heat loss | | | | | | | | | | | 162 |
| | KP | | | | 14,20 | 16 | -26 | 42 | 1 | 0,209 | 124,6 | 124,6 |
| | SUM | | | | | | | | | | 124,6 | 124,6 |
| 727-staff room | The total heat loss | | | | | | | | | | | 125 |
| | KP | | | | 18,84 | 16 | -26 | 42 | 1 | 0,209 | 165,4 | 165,4 |
| | SUM | | | | | | | | | | 165,4 | 165,4 |
| 728 | The total heat loss | | | | | | | | | | | 165 |
| | KP | | | | 2,22 | 16 | -26 | 42 | 1 | 0,209 | 19,5 | 19,5 |
| | SUM | | | | | | | | | | 19,5 | 19,5 |
| 729 | The total heat loss | | | | | | | | | | | 19 |
| | KP | | | | 11,67 | 16 | -26 | 42 | 1 | 0,209 | 102,4 | 102,4 |
| | SUM | | | | | | | | | | 102,4 | 102,4 |
| 730-staff room | The total heat loss | | | | | | | | | | | 102 |
| | KP | | | | 9,63 | 16 | -26 | 42 | 1 | 0,216 | 87,4 | 87,4 |
| | SUM | | | | | | | | | | 87,4 | 87,4 |
| 731-Utility room | The total heat loss | | | | | | | | | | | 87 |
| | KP1 | | | | 6,50 | 16 | -26 | 42 | 1 | 0,216 | 59,0 | 59,0 |
| | SUM | | | | | | | | | | 59,0 | 59,0 |
| 732-Technical room | The total heat loss | | | | | | | | | | | 59 |
| | EW | NE | | | 1,76 | 16 | -26 | 42 | 1,15 | 0,873 | 64,5 | 74,2 |
| | KP1 | | 3,07 | 4,56 | 14,00 | 16 | -26 | 42 | 1 | 0,209 | 122,9 | 122,9 |
| | KP2 | | 4,53 | 4,88 | 22,11 | 16 | -26 | 42 | 1 | 0,216 | 200,5 | 200,5 |
| | SUM | | | | | | | | | | 387,9 | 397,6 |
| 733-Utility room | The total heat loss | | | | | | | | | | | 398 |
| | EW1 | NW | | | 19,69 | 16 | -26 | 42 | 1,15 | 0,873 | 721,6 | 829,9 |
| | KP | | 4,27 | 2,81 | 12,00 | 16 | -26 | 42 | 1 | 0,216 | 108,9 | 108,9 |
| | IW2 | | 1,55 | 2,50 | 3,88 | 16 | 5 | 11 | 1 | 3,559 | 151,7 | 151,7 |
| | IW3 | | 2,73 | 2,50 | 6,83 | 16 | 5 | 11 | 1 | 3,559 | 267,2 | 267,2 |
| | SUM | | | | | | | | | | 1249,4 | 1357,6 |
| Tech 1 | The total heat loss | | | | | | | | | | | 1358 |
| | KP | | | | 46,30 | 16 | -26 | 42 | 1 | 0,216 | 420,0 | 420,0 |
| | SUM | | | | | | | | | | 420,0 | 420,0 |
| Tech 2 | The total heat loss | | | | | | | | | | | 420 |
| | KP | | | | 100,50 | 16 | -26 | 42 | 1 | 0,216 | 911,7 | 911,7 |

APPENDIX 2(23).

Heat loss calculation

| | | | | | | | | | | | | | |
|--|-----|----|------|-------|--------|----|-----|----|-------|----------------------------|----------------------------|-------------|-------------|
| | | | | | | | | | | SUM | 911,7 | 911,7 | |
| | | | | | | | | | | The total heat loss | | 912 | |
| Tech 3 | KP | | | | 16,31 | 16 | -26 | 42 | 1 | 0,216 | 148,0 | 148,0 | |
| | | | | | | | | | | SUM | 148,0 | 148,0 | |
| | | | | | | | | | | The total heat loss | | 148 | |
| Tech 4 | KP | | | | 42,50 | 16 | -26 | 42 | 1 | 0,216 | 385,6 | 385,6 | |
| | | | | | | | | | | SUM | 385,6 | 385,6 | |
| | | | | | | | | | | The total heat loss | | 386 | |
| The sum of heat loss of mansard = 51150 W | | | | | | | | | | | | | |
| Staircase | | | | | | | | | | | | | |
| Staircase 1 | EW1 | SE | 2,94 | 2,82 | 8,29 | 16 | -26 | 42 | 1,15 | 0,873 | 303,9 | 349,4 | |
| | EW2 | SW | 8,75 | 2,82 | 24,68 | 16 | -26 | 42 | 1,15 | 0,873 | 904,3 | 1040,0 | |
| | WD1 | SE | | | 3,55 | 16 | -26 | 42 | 2,105 | 1,553 | 231,6 | 487,4 | |
| | WD2 | SW | | | 1,60 | 16 | -26 | 42 | 1 | 1,553 | 104,4 | 104,4 | |
| | CR | | | | 31,50 | 16 | -26 | 42 | 1 | 1,103 | 1459,3 | 1459,3 | |
| | KP | | | | 36,68 | 16 | -26 | 42 | 1,15 | 0,216 | 332,8 | 382,7 | |
| | | | | | | | | | | | SUM | 3336,1 | 3823,1 |
| | | | | | | | | | | | The total heat loss | | 3823 |
| Staircase 2 | EW1 | NW | 7,20 | 29,58 | 212,98 | 16 | -26 | 42 | 1,1 | 0,308 | 2756,5 | 3032,2 | |
| | WD1 | NW | | | 1,30 | 16 | -26 | 42 | 1,1 | 1,416 | 77,3 | 85,0 | |
| | WD2 | NW | | | 24,40 | 16 | -26 | 42 | 1,1 | 1,416 | 1451,1 | 1596,2 | |
| | WD3 | NW | | | 2,06 | 16 | -26 | 42 | 1,1 | 1,416 | 122,5 | 134,8 | |
| | WD4 | NW | | | 6,78 | 16 | -26 | 42 | 1,1 | 1,416 | 403,2 | 443,5 | |
| | KP | | | | 42,85 | 16 | -26 | 42 | 1 | 0,216 | 388,7 | 388,7 | |
| | s11 | | 6,98 | 2,00 | 13,96 | 16 | -26 | 42 | 1 | 0,48 | 281,4 | 281,4 | |
| | s12 | | 6,98 | 2,00 | 13,96 | 16 | -26 | 42 | 1 | 0,23 | 134,9 | 134,9 | |
| | s13 | | 6,98 | 2,00 | 13,96 | 16 | -26 | 42 | 1 | 0,12 | 70,4 | 70,4 | |
| | s14 | | 6,98 | 1,52 | 10,61 | 16 | -26 | 42 | 1 | 0,07 | 31,2 | 31,2 | |
| | | | | | | | | | | | SUM | 5717,2 | 6198,3 |
| | | | | | | | | | | | The total heat loss | | 6198 |
| Staircase 3 (near cafe) | EW | NE | 5,48 | 4,70 | 25,76 | 16 | -26 | 42 | 1,1 | 0,873 | 943,9 | 1038,3 | |
| | WD1 | NE | | | 17,80 | 16 | -26 | 42 | 1,1 | 0,852 | 636,6 | 700,3 | |
| | WD2 | NE | | | 4,48 | 16 | -26 | 42 | 1,1 | 1,724 | 324,4 | 356,9 | |
| | KP | | | | 13,34 | 16 | -26 | 42 | 1 | 0,216 | 121,0 | 121,0 | |
| | s11 | | | | 13,60 | 16 | -26 | 42 | 1 | 0,48 | 274,2 | 274,2 | |
| | s12 | | | | 9,99 | 16 | -26 | 42 | 1 | 0,23 | 96,5 | 96,5 | |
| | s13 | | | | 0,00 | 16 | -26 | 42 | 1 | 0,12 | 0,0 | 0,0 | |
| | s14 | | | | 0,00 | 16 | -26 | 42 | 1 | 0,07 | 0,0 | 0,0 | |
| | | | | | | | | | | | SUM | 2396,7 | 2587,2 |
| | | | | | | | | | | The total heat loss | | 2587 | |
| Staircase 4 | EW1 | | 7,00 | 33,15 | 232,02 | 16 | -26 | 42 | 1,1 | 0,873 | 8503,2 | 9353,5 | |
| | EW2 | | 4,37 | 24,66 | 107,76 | 16 | -26 | 42 | 1,15 | 0,873 | 3949,5 | 4541,9 | |
| | WD | SW | 1,50 | 1,50 | 13,50 | 16 | -26 | 42 | 1,15 | 0,852 | 482,8 | 555,2 | |

APPENDIX 2(24).**Heat loss calculation**

| | | | | | | | | | | | |
|---|--|--|--|-------|----|-----|----|---|-------|--------|--------------|
| KP | | | | 28,27 | 16 | -26 | 42 | 1 | 0,216 | 256,5 | 256,5 |
| CR | | | | 28,27 | 16 | -26 | 42 | 1 | 1,103 | 1309,6 | 1309,6 |
| SUM | | | | | | | | | | ##### | 16016,7 |
| The total heat loss | | | | | | | | | | | 16017 |
| The sum of heat loss of staircase = 28640 W | | | | | | | | | | | |
| The sum of heat loss of building = 342240 W | | | | | | | | | | | |
| The total heat load (with losses in the pipes - 7%) = 366197 W | | | | | | | | | | | |

APPENDIX 2(1).
Heat loss calculation